



Prishtinë, June 24th 2008
ERO Code: D_107_2008

Board of the Energy Regulatory Office

Taking into account:

1. Provisions of the Sections 15.2 and 25 of the Law on Energy Regulator amended by Law no: 03/L-080;
2. Provisions of the Section 49.2 of the Rule on Licensing of Energy Activities in Kosova and Sec. 4 of the Transmission System Operator's License,
3. KOSTT J.S.C's request for derogation in implementing some provisions of the KOSTT J.S.C's Network and Measurement Codes, dated May 5th 2008, **in its session held in June 24th, 2008 adopted this:**

DECISION

- I. **KOSTT J.S.C is allowed** the derogation in implementing the provisions of sections of Network and Measurement Codes as in annex to this decision.
 1. All other provisions of the Network Code, Transmission System Operator's measurement code will remain effective.
 2. This decision is written in three languages: Albanian, Serbian and English and will be published in the official ERO web-page.
 3. The unsatisfied party may file a complaint against this decision before the court of respective jurisdiction within 14 days since the date of approval or date of publication of this decision into the official ERO web-page.
 4. This decision is effective since the date of issuance or date of publication into the official ERO web-page.

ERO Board:

Ali Hamiti, Chairman

Theranda Beqiri, Member



Derogated provisions of Network Code

No.	Part of the Code	Section	Paragraph	Derogation period (in years)	Reason for the request
1.	Operational code	5.5.3 Network stability and overcharge	5.5.3.3	6 months	Routine studies on safety are missing, PSSE/EMS equipment are expected.
2.	Balance Code	3.9 Power program	3.9.1.1	6 months	Intent to extract the power program, PSSE licenses through which the respective analyses will be done, are requested.
			3.9.1.2		
			3.9.1.3		
			3.9.1.4		
3.	Operational Planning Code	3.4.3 Transmission System obstacles	3.4.3.1	6 months	System safety evaluation is not possible for medium-term and short-term planning.
		3.12 Power System Safety Evaluations	3.12.1	6 months	System safety evaluation is not possible for medium-term and short-term planning.
			3.12.2		
			3.12.4		

Derogated provisions of the Measurement Code

No.	Code	Section	Paragraph	Derogation period in years	Reason for request
		8.2 Capacity (power)and Energy Measurement	8.2.2.8	6 months	In SS. Ferizaj, the measurement core serves as protection as well.