

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 1 of 103</i>
<i>Office: Long-term Planning and Development</i>		

# **TRANSMISSION DEVELOPMENT PLAN**

## **2021-2030**

**October 2020**

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 2 of 103</i>
<i>Office: Long-term Planning and Development</i>		

## CONTENTS

<b>1. INTRODUCTION .....</b>	<b>5</b>
1.1 Legal Requirements .....	5
1.2 Current Kosovo Transmission System.....	7
1.3 Long-term planning objectives of the transmission system.....	9
1.4 Content of the Plan.....	11
<b>2. PLANNING PROCESS OF TRANSMISSION NETWORK.....</b>	<b>12</b>
2.1. Introduction .....	12
2.2. Transmission System Planning Methodology .....	13
2.3. Planning process for the revitalization of the existing network .....	14
2.4. Transmission projects cost-benefit estimation methodology.....	19
2.4.1 Benefit indicators .....	20
<b>3. ELECTRICITY GENERATION AND LOAD FORECAST .....</b>	<b>23</b>
3.1. Introduction .....	23
3.2. Historical information of the load, and current situation .....	23
3.3. Demand profile .....	24
3.4. Maximum annual load forecast 2021 - 2030.....	29
<b>4. GENERATION CAPACITIES OF KOSOVO'S ELECTRICITY SYSTEM.....</b>	<b>30</b>
4.1 Introduction .....	30
4.2 Current generation capacities in Kosovo .....	30
4.3 Projection of the development of new generation capacities 2021 - 2030 .....	32
<b>5. KOSOVO'S TRANSMISSION NETWORK DEVELOPMENT PROJECTS (2021-2030) .....</b>	<b>34</b>
5.1 The incentive factors of the development plan.....	34
5.2 Implemented projects 2007-2019.....	35
5.3 Transmission network infrastructure development 2021-2030.....	38
5.3.1 Introduction.....	38
5.3.2 List of new development projects planned for the period 2021-2030.....	39
5.3.2.1 ..... List of new projects in the category of transmission network reinforcement	39
5.3.2.2 ..... List of new projects in the category: Load support	42
5.3.2.3 ..... Projects planned for the category: Re-vitalization of KOSTT substations	44
5.3.2.4 ..... Projects planned in the category: Supporting transmission system operation	44
5.3.2.5 ..... Generation support project categories	45
5.4 Technical description of transmission planned projects for the period 2021 -2030 .....	46
5.4.2.1 Projects: Re-vitalization of 110 kV lines .....	60
5.4.3 Load support projects.....	66
5.4.4 Projects: Substations Re-vitalization .....	76
5.4.5 Projects: Advancement of the monitoring, control and metering system of the Transmission System	77
5.4.6 Projects of category: Generation support (in implementation).....	80
<b>6. ENVIRONMENTAL IMPACTS.....</b>	<b>84</b>
6.1 Environmental protection .....	84
6.2 Environmental problems in the transmission system .....	84
6.2.1 Environmental problems caused by the lines.....	84
6.2.2 Environmental problems caused by the substations .....	85
6.2.3 Caution on the other environmental impacts .....	85

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 3 of 103</i>
<i>Office: Long-term Planning and Development</i>		

6.2.4	Activities and advancements during the period .....	86	
6.3	Environmental plans .....	86	
<b>7.</b>	<b>EXPECTED RESULTS FROM TDP 2021-2030 IN THE TRANSMISSION SYSTEM DEVELOPMENT</b>		<b>87</b>
7.1	Actual state of the network in 2020 .....	88	
7.2	Development of the transmission network capacities in the next 10 years .....	91	
7.3	N-1 security criterion .....	93	
7.4	Quality of supply and efficiency .....	94	
<b>8.</b>	<b>REFERENCES</b> .....	<b>103</b>	

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 4 of 103</i>
<i>Office: Long-term Planning and Development</i>		

### **Abbreviations**

ENTSO/E – (European Network of Transmission System Operators for Electricity)

KOSTT – Transmission System, and Market Operator JSC

KEDS – Kosovo Electricity Distribution and Supply Company J.S.C.

DSO – Distribution System Operator

OPGW – Optical Ground Wire

TSO – Transmission System Operator

PSS/E- Power System Simulator/Engineering

TDP – Transmission Development Plan

EES –Power system

SCADA/EMS – Supervisory Control and Data Acquisition/Energy Management System

SECI – South East Cooperative Initiative (Regional transmission planning project)

EMS – Environment management system

CBA – Cost Benefit Analyses

IT – Information Technology

ERO – Energy Regulatory Office

KfW - “Kreditanstalt für Wiederaufbau”

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 5 of 103</i>
<i>Office: Long-term Planning and Development</i>		

## 1. INTRODUCTION

The Transmission Development Plan (TDP) 2021-2030 represents Kosovo's network development plan for the next 10 years. This 10 year plan introduces projects that are needed to ensure a reliable and secure operation of the transmission system, in order to achieve security of supply, support the energy market and competition, support the integration of renewable and complementary thermal sources.

Electricity sector as one of the most important industrial sectors in the economy of Kosovo should be developed and planned appropriately and in time. Transmission network, which is operated by **KOSTT**, plays an important role in the energy and electricity system enabling the transmission of power from local generators and imports to large customers and distribution nodes.

The development of the society and the growing dependence on electricity requires a secure, reliable and efficient transmission network. The growing dependence on electricity means that tolerance to the power outage should be minimal, and the over-extended outages are unacceptable.

In future, this will inevitably require high standards of supply from the transmission network.

Since the establishment of KOSTT until now in 2020, capital investments amounting to about 246M€ have been made in the transmission network, mainly in the development and reinforcement of the transmission network capacities, revitalization and advancement of support systems. Based on all measurable performance indicators recorded in the last decade, ongoing investments in the new infrastructure of the transmission network; modernization of transmission system support systems; revitalization of substations and lines have contributed to an ongoing increase of security, reliability and performance of the transmission system operation. All this has helped stabilize the electricity sector in the Republic of Kosova.

The requirements for increasing the security of supply and development of transmission capacities in order to support the increasing load, integration of generation from both conventional and renewable sources represents the main factor for KOSTT to continue with investments in the network for the years to come.

Achievement of adequate security of electricity supply, further market integration and development, integration of new generating capacities, are related to proper transmission system planning. Since the demand for energy and generation varies; or since the regional transmission network becomes even more interconnected; or new loads or generation are connected to the network, the power flows in the transmission network will vary. To accommodate these changes in power flows, it is necessary to reinforce the transmission network, so as to maintain the level of security, performance and efficiency of the transmission system.

### 1.1 Legal Requirements

Related to the above-mentioned responsibilities on the transmission system development and legal obligations, **KOSTT** hereby drafts the Transmission Development Plan (**TDP**), which represents one of the main foundations of development planning of **KOSTT**. The importance of application such document is faced also in the legislative requirements related to the preparation and treatment of this document and as such belong to the primary and secondary legislation. In following are presented the legal requirements for compiling of this document.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 6 of 103</i>
<i>Office: Long-term Planning and Development</i>		

### **1.1.1 Law on Energy**

Each year the Electricity Transmission System Operator, Electricity Distribution System Operator, Thermal Energy Distribution System Operator, and Natural Gas Transmission System Operator shall submit to the Regulator the ten (10) year network development plan, based on the current and estimated demand and supply, after consultation with all relevant stakeholders. The network development plan contains efficient measures, in order to guarantee system adequacy and security of supply.

### **1.1.2 Law on Electricity**

TSO shall be responsible for preparation of ten (10) year plans in compliance with the Law on Energy and fulfilment of obligations related to such plans.

### **1.1.3 Law on Energy Regulator**

The Regulator shall examine whether the ten (10) year system development plan submitted by the Transmission System Operator covers all investment needs identified during the consultation process, and may require the Transmission System Operator to amend its ten (10) year system development plan. The Regulator shall monitor and evaluate the implementation of the ten (10) year transmission network development plan.

### **1.1.4 Licenses for the Transmission System Operator**

Pursuant to Article 10 of the Law on Energy and Article 16 sub-paragraphs 1.11, 1.12 and 1.13 of the Law on Electricity, the Licensee shall develop and publish a medium-term (5 years) investment development plan that shall derive from long-term development plan (10 years) of transmission system. Such development plans shall be drafted in conformity with the applicable legislation in consulting with current and potential system users. Before its publication, the plan shall be submitted to ERO for approval. The Regulator shall monitor and evaluate the implementation of the ten (10) year system development plan. Before the publication of the development plan, it shall be aligned with those of the DSO and shall be submitted to ERO for approval. During the planning of the operation of the electricity transmission system, the Licensee shall cooperate with the Market Operator, the Distribution System Operator, the transmission system users and the neighbouring transmission system operators.

### **1.1.5 Grid Code – Planning Code**

Each year TSO will prepare and submit to Energy Regulatory Office Ten (10) Year Transmission Development Plan based on current and anticipated supply and demand after consultation with all relevant stakeholders.

### **1.1.6 Rule on licensing energy activities in Kosovo**

The Applicant who is applying for Transmission System Operator License, in addition to the requirements of Article 8 of this rule, shall submit to the Regulator the Transmission Development Plan, as defined in Article 10 of the Law on Energy, including the system development's impact in the tariffs approved by ERO.

### **1.1.7 ENTSO-E Requirements:**

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 7 of 103</i>
<i>Office: Long-term Planning and Development</i>		

According to the article of the (EC) Regulation No. 714/2009 of the 3-rd package that defines the coordination of the operation and development of the transmission system "an extensive network plan for the community-wide should include modeling of integrated network, scenario development, an adequacy concept generation and an assessment of the resilience of the system". Furthermore, **TDP** (Transmission Development Plan) should "build on national investment plans and, if appropriate under the guidelines for network development".

ENTSO-E publishes the 10-year Transmission Development Plan every two years, which contains the outlined and agreed national plans of all countries of Continental Europe operating in the synchronous area.

Pursuant on the above mentioned legal obligations, **KOSTT** is obliged to draft and after approval from **Energy Regulatory Office**, to publish and implement such document, which is drafted in full compliance with Energy Strategy of Kosovo.

## 1.2 Current Kosovo Transmission System

Kosovo's transmission network is developed over the last 60 years in several stages of construction, expansion, reinforcement and consolidation. The current transmission network (2020) consists of 1410.5 km of lines, including:

- 279.5 km at 400 kV voltage level,
- 238.5 km at 220 kV voltage level, and
- 892.5 km at 110 kV voltage level

The installed transformer capacity of the horizontal transmission network consists of 16 autotransformers with a total capacity of 3750 MVA, including:

- 1200 MVA auto-transformer at 400/220 kV voltage level (3 ATR)
- 1200 MVA auto-transformer at 400/110 kV voltage level (4 ATR)
- 1350 MVA auto-transformer at 220/110 kV voltage level (9 ATRs)

The installed transformer capacity of the vertical transmission network consists of 65 transformers with a total capacity of 2320 MVA, including:

- 160 MVA transformer at 220/35/10 kV voltage level and at 220/10 kV voltage level (4 TR)
- 340.5 MVA three-pole transformer 110/35/10 kV (8 TR-3winding)
- 618 MVA transformer at 110/35 kV voltage level (19 TR)
- 1201.5 MVA transformer at 110/10 kV voltage levels (34 TR)

In the frame within the high voltage transformers connected to the transmission network that are not managed by KOSTT are:

- 320 MVA 220/35 kV ( 2 TR- Feronikel)
- 126 MVA, 110/35/6.3 kV and 110/6.3 kV ( 4 TR Trepca, actually 3 out of service)
- 40 MVA, 110/6.3 kV ( 2 TR- Sharr-Cem)
- 20 MVA, 110/6.3 kV ( Ujman- IberLepenci)

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 8 of 103</i>
<i>Office: Long-term Planning and Development</i>		

In total 6399 MVA, transformer capacities are connected to the transmission network according to the end of 2017 year.

Kosovo Transmission Network operates with 37 substations of different voltage levels, as follows:

- 1 substation 400/220 kV,
- 2 substations 400/110 kV
- 3 substations 220/110 kV
- 2 substations 220/35/10 kV and 220/10 kV
- 8 substations 220/35/10 kV
- 6 substations 110/35 kV, and
- 15 substations 110/10(20) kV

The transmission network also includes three substations managed by the industry such as Feronikel (220/35 kV), Trepça (110/35/6.3 kV) and Shar-Cem (110/6.3 kV).

Kosovo transmission network is characterized as a fairly well connected network with the regional network with lines

- 400 kV
  - SS Kosovo B - SS Koman (Albania)
  - SS Kosovo B - SS Nish (Serbia)
  - SS Peja 3 - SS Ribarevina (Montenegro)
  - SS Ferizaj 2 - SS Shkupi 5 (North Macedonia)
- 220 kV
  - SS Prizreni 2 - SS Fierza (Albania)
  - SS Podujeva - SS Krushevc (Serbia)

Two 110 kV cross-border lines with Serbia are also in operation, SS Vallaq - SS Novi Pazar and SS Berivojce - SS Bujanovc.

Regarding the interconnection capacity of the Kosovo transmission network, it is considered to be a fairly well connected network to the regional network through four 400 kV lines and two 220 kV lines in the regional network. There are also two 110 kV cross-border lines that have small transmission capacities and mainly operate in radial (island) mode.

The geographical extension of the Kosovo Power System according to the current situation (2020) is shown in Fig. 1-1.




Figure 1-1. Geographical extension of the transmission network in the territory of the Republic of Kosovo according to the current situation 2020

### 1.3 Long-term planning objectives of the transmission system

The planning and development of the transmission network is a dynamic and complex process. Transmission system planning is a process aimed at making decisions for the development of new or reinforcement of existing transmission system elements, to ensure long-term energy forecasts and supply, so as to make possible the supply of consumption for the long term forecast domain. Planning as a process involves a number of activities, such as network development in relation to forecast of electricity demand, forecast to generation, enabling the identification of necessary reinforcements and extensions required to achieve a reliable and environmentally sound network operation. Although **TDP** uses as a reference the

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 10 of 103</i>
<i>Office: Long-term Planning and Development</i>		

prediction for a defined period provided in the Long-Term Energy Balance, the plan must also follow the strategic developments of the transmission system in the long term period.

The planning process has evolved over the time as a result of the restructuring process of the energy market and differs from the earlier concept of centralized planning applied for vertically integrated companies.

The main reasons for the difference are:

- Uncertainties coming from the market environment and input data.
- Uncertainties in the development of gas generation and infrastructure
- Different objectives of various network users (generators, traders, suppliers, customers and network operators),
- Incompatibility - disproportion between technical, economic, environmental and social requirements,
- Uncertainties derived from the integration of energy from renewable sources, especially those connected to the distribution network, and
- Delays in the expropriation of properties associated with the expansion of the transmission infrastructure.

Also the need for regional market integration requires enhancement and strengthening of interconnection capacities, which affects the planning process at national level. Network development options are based on Planning Code and general planning rules recommended by the **ENTSO-E**. The defining methodology, which relies on the N-1 security criteria, is the basic methodology applied in this plan, with the aim of identifying and defining the list of projects required for the development of the transmission network. Zonal forecasting of the load and generation is fundamental in determining the required transmission infrastructure in the long-term

This plan includes information on the development and reinforcements expected to occur in the Kosovo transmission network for the next 10 years, in the following areas:

- Construction of new transmission and transformation capacities,
- Reinforcement of existing transmission and transformation capacities,
- Construction of interconnection lines with neighboring countries,
- Revitalization of existing high voltage facilities (lines and substations)
- Development of transmission system support systems
- New connection of generation and load.

The main objective of ten-year plan is to identify projects which will increase capacity, reliability and efficiency of the transmission network operation with direct support for the security of quality electricity supply to customers.

This plan will inform customers, energy market participants, energy producers, prospective investors on the transmission development plan for the next ten years.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 11 of 103</i>
<i>Office: Long-term Planning and Development</i>		

This document presents development plan drafted in **KOSTT**, covering a period of ten years, from 2021 until 2030, in line with the **ENTSO-E** requirements, where the 2020 year represents the reference year, or the so-called year zero.

The document is a continuation of previous plans and includes the necessary changes identified during the previous and current year. All information in the development plan such as: project details, expected date of project commissioning, applications for connection to the transmission network that occurred during the previous year and continue to be completed until end of 2020, are taken into consideration in the drafting of this document.

For the drafting of this development plan relevant calculations were carried out with the use of **PSS/E** software, simulating power flows, shorts circuits and dynamic processes in computer models in the system, based on data provided by **KOSTT** and network users, as well as based on demand forecasts for the next 10 years.

Load and generation forecast for the next 10 years. Forecasting of the load and generation for the next 10 years is based on the data from the Long-term Energy Balance (2019 – 2028). Data on interconnections expected to be developed in the region, are provided by studies made under the Planning Group for Regional Transmission Network- **SECI**, with the contribution of **KOSTT** through its representatives, as well as the 10 year Transmission Development Plan published every two years by **ENTSO-E**.

For each planning year, relevant power flow studies have been conducted, conveying at the same time the demand increase for maximum load and that for two critical regimes: winter and summer.

Calculations of breakdowns in different time periods have also been carried out. Based on calculations results, it is possible to provide estimates of how the network will operate for the estimated next years. Bottlenecks/overloads in the network were identified and possible solutions have been presented, including analysis of their impact to improve the transmission network operational performance.

The transmission system is also analyzed in terms of minimal load operating conditions, with the aim of identifying possible problems of the network with over-voltages that can occur in summer minimal load regimes. In this case, the regional study was used, which examines the problem of overvoltages in the network of Southeast Europe and the solution of this problem, which has already appeared in our region.

#### **1.4 Content of the Plan**

**TDP** is structured in 8 chapters including the Introduction:

##### **Chapter 1**– Introduction

Chapter 2 – Planning process of transmission network -

Grid Code Technical Requirements - the data collection process, planning criteria and standards, and the configuration of substations according to the voltage level of 400 kV, 220 kV and 110 kV are presented.

**Chapter 3** - Presents the electricity demand forecast, broken down in the consumption of the past three years and forecasted consumption for the next 10 years.

**Chapter 4** - List of existing generators and planned ones. It is also presented the renewables generation and **KOSTT** policies in support of this technology.

**Chapter 5** - Describes the **KOSTT** network transmission, and interconnection with its neighbors. A part of this chapter describes in details the future developments of the network.

**Chapter 6** - Includes access of environmental planning in relation to the **Transmission Development Plan**.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 12 of 103</i>
<i>Office: Long-term Planning and Development</i>		

**Chapter 7** - It contains summarized results expected from implementation of the **Transmission Development Plan**.

**Chapter 8** - Contains a list of references.

## 2. PLANNING PROCESS OF TRANSMISSION NETWORK

### 2.1. Introduction

One of the main **KOSTT** objectives is development of the transmission system with the purpose of safe, efficient and reliable operation in order to enable electricity transmission, fulfilling the demand in compliance with the legal requirements. **Transmission System Operator** has planned developments of the network based on long-term electricity needs. A requirement for electricity transmission depends on many factors: increased consumption, installation of new generating units, new cross-border lines and regional, transit of electricity, development of heavy industry, development of energy market, etc.

The need for reinforcements in the transmission network is determined based on the study of network performance against the planned technical standards outlined in the Grid Code respectively Planning Code. The Grid Code covers the operational procedures and provisions governing the interaction between **KOSTT** and users of the Transmission System in Kosovo. This code also includes the processes of planning, connection, operation and balances system in normal and emergency situations. Processes include different periods based on the situations in the past, current situation and long-term domain.

The Planning Code specifies technical criteria and procedures to be applied by **KOSTT** in planning and development of the Transmission System of Kosovo. Even users of the Transmission System during the planning and development of their systems should consider the Planning Code. This code also sets requirements for the collection of reliable information from users, so that **KOSTT** can make planning and development of transmission system in Kosovo.

Based on Article 14 of the 'License of the Transmission System Operator' **Transmission System Operator** also has developed the basic planning criteria which are detailed in the document approved by the **ERO**, "Transmission System Security and Planning Standards". This document defines a range of criteria and methodologies that **KOSTT** should adopt (enforce) in the planning process of developing the transmission network in Kosovo.

The 400 kV, 220 kV and 110 kV network planning criteria and the medium voltage network (35 kV and 10 (20) kV) managed by **KOSTT**. Kosovo's transmission system in the 400 kV and 220 kV level has technical and economic characteristics which differ from the 110 kV network. Investment costs and dimensioning criteria are much higher than those of the 110 kV. The transmission system is interconnected with regional transmission systems through a 400 kV and 220 kV network, thus the impact of network investments in the 400 kV and 220 kV voltage is not isolated, but rather has a regional character.

**KOSTT** has developed the transmission development strategy, focused in strengthening/ development of the 400 kV and 110 kV network, while the 220 kV network will not be further developed, except for specific cases where no other solutions can be found.

Transmission network planning is made according to the criteria defined in the Grid Code, considering the fulfillment of N-1 criteria, meaning that the system must be capable of normal operation in case of occurrence of the fault in the network (in Kosovo or in other systems) and the loss of one of each element such as:

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 13 of 103</i>
<i>Office: Long-term Planning and Development</i>		

- *airline or cable lines*
- *transformer,*
- *compensator, reactor*
- *generator*
- *a busbar from the double busbar system (the case of emergency failures according to ENTSO-E).*

In case lost of one of each above elements as a result of failures, transmission system must fulfill the following operation conditions:

- *transmission lines should not be loaded above their thermal limits,*
- *reduction of the supply capacity is not allowed*
- *level of voltage and speed change cannot exceed allowed limits,*
- *transient and dynamic stability of the Power System should not be endangered, and*
- *power transformers should not be over-loaded.*

The 110 kV network, which development is done in accordance with the Transmission Connection Charging Methodology of **KOSTT**, includes all equipment, voltage 110 kV (lines and facilities) transformers 110/10 (20) kV and 110/35 kV and 220/35/10(20) kV transformer including respective fields.

In normal operating conditions the performance of the transmission system should be in accordance with operating criteria outlined in the Grid Code.

## **2.2. Transmission System Planning Methodology**

The approach of the transmission network planning methodology consists of the following steps:

- *Collection of input data (creation of data base for computer modeling of the network).*
- *Definition of different scenarios taking into account factors strengthening the development of generation, load, applications for connection, balance of power system, exchanges etc.*
- *The creation of computer models of the network transmission format to **PSS/E**.*
- Evaluation of network performance for different scenarios and different operating conditions against the technical requirements of the Grid Code and other applicable standards.
- *Cost benefit analysis for each scenario according to the ENTSO-E methodology,*
- Determining the optimal development plan of the transmission network

Figure 2-1 shows the planning methodology algorithm for the capacity strengthening and operational performance of the transmission system.




Figure 2-1 The planning process of Transmission network development

### 2.3. Planning process for the revitalization of the existing network

#### 2.3.1 Introduction

The transmission system consists of a number of elements, such as lines, cables, transformers, circuit breakers, separator and much more. Each EES component has an inherent risk of failure. Many external factors affect the potential failure of components, damages by third parties (human/animal), and trees. Atmospheric conditions such as temperature, humidity, pollution, wind, rain, snow, ice, lightning and solar effects can have a crucial role in the failure of components. It is frequently assumed that the life cycle of installed electrical equipment/ components is about 35-40 years. However, to estimate the lifetime period of various components, it is necessary to consider multiple factors, such as the range of extreme operating conditions and environment, as well as the changing level of previous maintenance. Most transmission companies use components beyond 40 years, if they are not faced with extreme occurrences, such as atmospheric discharges. Any short circuit in and near the substation causes large power flows

currents over the equipment, and the more frequent they are, the more likely it becomes that the equipment will suffer a breakdown. Substations near generation are at the highest risk from this occurrence, where the short circuit currents are larger.

The statistical rate of failures increases over the years based on the bathtub curve as presented in Figure 2-2. The bathtub curve consists of three periods: (1) The period of failures in the beginning of the commissioning of the equipment with a high rate of continued failure (2) second period “optimal life cycle” with the lowest and most consistent rate of failure. The third period (3) “end of the life cycle” is the critical period of the component with a high degree of failure.




Figure 2-2 The bath tub curve: hypothetical failure rate depending on time in operation

### 2.3.2 Planning methodology for the network’s revitalization

The revitalization plan of the transmission system facilities such as overhead lines, transformers, cables and substations, generally depends on the technical condition, their age and intensity of use of such facilities in retrospective. The revitalization plan of transmission network facilities is developed as follows:

- **Overhead lines:** Their revitalization depends on two factors: their age and level of losses incurred in the long-term. For phase and protective conductors, insulators, bridges, exceeding 50 years represents a condition for inclusion in the revitalization list. The frequency of failures in line is an additional indicator for the selection of the line in the revitalization list.

In terms of losses, the revitalization list includes cross lines of 150 mm<sup>2</sup>, which are also connected with the first factor, as in the initial transmission network development phase (1950-1970) 110 kV lines are built with cross section conductors of 150 mm<sup>2</sup>. The concept of developing new capacities in transmission network lines focus on 400 kV and 110 kV lines, with no intended further development for the 220 kV lines. This development concept is being applied in almost all transmission systems of **ENTSO-E**. 220 kV lines are considered as older lines (> 50-60 years) as their construction was mainly conducted in the 60s and 70s. The concept of European countries is that 220 kV lines will be gradually upgraded in 400 kV lines, mainly

using only their route. Problems with expropriation of private property for purposes of building new lines are significant in all European countries.

The following figure shows the age of the transmission lines according to the voltage level that are in operation.




Figure 2-3. The current age of the lines in operation in the transmission network according to the voltage level

- **Power transformers:** The plan to replace power transformers of the transmission network is based on their expected lifetime, estimated at 40 years. Another important factor that influenced the inclusion of transformers in the list of replacements is their real situation, monitored by maintenance teams through periodic testing. Historical statistical data on events on particular transformers (level of load, number and frequency of transformer protections, gas analysis, etc.) are important factors in the selection of transformers which should be replaced with new transformers. In specific cases where the transformer's status is considered to be good, it may continue to operate even over the age of 40 years. Figure 2-4 shows the age of 65 power transformers installed in the substations at the border with the distribution operator. From the figure it can be seen that 13 transformers have passed the projected lifespan, five others will reach the critical age value within the next three years and another 19 transformers, after 10 years in operation, will reach the age of 40.

Figure 2-5 shows the age of 16 auto-transformers operating in the transmission network, where one auto-transformers in SS Prizren 2, has passed the age of 40 years. Within the next 10 years and 6 auto-transformers with pass the critical age.




Figure 2-4. Current transformers age in operation in the power transmission network




Figure 2-5. Current age of auto-transformers in operation in the transmission network

- **Substations (lines fields and transformers):** Revitalization plan for substations fields, which are included in the defined transmission network boundaries, is also based on the age of the facilities and their factual situation. Priority in revitalization lies with substations with a high impact on the transmission system, but also all substations the life cycle of which has passed 40 years. Systematic replacement of oil-based circuit breakers with SF6 gas is a **KOSTT** objective as per the development and investment plan. In addition, the replacement includes all elements of relevant fields (transformer, lines) installing a motorized separator commanded through the **SCADA/EMS** system. The double busbar system with a connecting field is preferred for substations which have sufficient space.

Access to planning methodology for transmission network revitalization consists of the following steps:

- *Collection of input data, historical frequency of breakdowns in facilities, lines, cables, transformers etc., age of equipment and general evaluation of the technical state of electric equipment for the reference year (the current year).*
- *Analyze the performance of equipment and technology in order to identify new technologies provided by the global market that can resolve issues in the performance of the equipment.*
- *Identify equipment in locations, or lines/cables to be included in the process of verifying the underperformance.*
- *Analyze the need for improvement or advancement of equipment. If equipment are not necessary, and not worth the investment, a decision to be made to decommission them. Otherwise, the process continues with a detailed assessment of the state of problematic equipment.*
  - Analyze possible options of revitalization with a regular maintenance process, or inclusion in revitalization projects in the Development Plan.

In figure 2-6 is presented the algorithm of network refurbishment planning methodology.




Figure 2-6 Planning process for revitalization of transmission system

#### 2.4. Transmission projects cost-benefit estimation methodology

In accordance with the Regulation ERO/No. 13/2017 on the Assessment of Capital Projects in the Transmission and Distribution Network in the Electricity Sector, KOSTT is obliged to prepare the cost-benefit assessment of projects deriving from the 10-year Transmission Development Plan related to the 5 year time period, namely the 5 year investment and development plan of transmission.

The aim of the project's cost-benefit analysis is to determine the impact of the network infrastructure and transmission system development in the society's socio-economic welfare. The modified CBA (cost-benefit analysis) methodology published by ENTSO-E has been used by KOSTT in accordance with the ERO Regulation no. 13/2017 approved by the Energy Regulatory Office. This methodology compares the impacts of each project based on a range of indicators set by ENTSO-E. Assessment of transmission network projects is a complex task due to different categories of projects. For some projects mainly related to security of supply, efficiency, integration of renewable resources, new interconnection etc., it is easier to identify the measurement parameters of a significant number of indicators. Whereas for some projects that are mainly related to the transmission system's support processes, it is very difficult to weigh the assessment indicators as they are not directly related to any of the indicators set by ENTSO-E. For example projects related to software platforms, adaptation of IT systems according to requirements and changes occurring in ENTSO-E, defence and monitoring measurement systems, etc. do not have specifics that may relate to indicators such as security of supply, efficiency, etc. These projects are necessary for the secure and efficient operation of the transmission system, but nevertheless they cannot be weighed and cost-benefited in terms of the indicators set by the CBA methodology.

The CBA methodology is based on the following factors:

- *Security of supply*
- *Safety of transmission system operation*
- *Integration of generation, RES, reduction of CO2*
- *Network efficiency*
- *Promotion of the market for socio-economic benefit of the society*
- *Project's cost calculation (fixed and variable)*
- *Environmental and social impacts*

The table below describes the structure of projects for which the CBA can be applied.

Table 2-1 Categorization of projects for implementation of CBA

Projects/Network reinforcement: <ul style="list-style-type: none"> <li>• New line or cable</li> <li>• New transmission substation</li> <li>• New Transformer (or Replacement)</li> <li>• Upgrading the existing line capacity</li> <li>• Network for the connection of conventional new generators and RESs</li> <li>• Interconnection line</li> <li>• Reactor or compensator</li> </ul>	CBA indicators can be fully implemented
--	---

<ul style="list-style-type: none"> <li>Energy accumulators for the "storage" needs)</li> </ul>	
<b>Projects / Load Support:</b> <ul style="list-style-type: none"> <li>New substation with interconnection lines</li> </ul>	All of the CBA indicators can be fully implemented, efficiency gains are mainly transferred to the distribution network
<b>Projects / Revitalization:</b> <ul style="list-style-type: none"> <li>Substation as a whole</li> <li>Specific line fields or transformers</li> </ul>	The CBA indicators may be partially implemented
<b>Projects / system support</b> <ul style="list-style-type: none"> <li>Measuring and protection systems</li> <li>IT market systems</li> <li>SCADA / EMS systems</li> <li>Telecommunication systems</li> <li>GIS systems</li> <li>Software for system analysis, etc.</li> </ul>	The CBA indicators cannot be applied. They are necessary based on the Grid Codes and the requirements of ENTSO-E

### 2.4.1 Benefit indicators

The assessment of transmission network projects represents a complex process which entails the linkages between all default costs needed in project development and the project's expected benefits by examining environmental and social impacts as inevitable factors for any kind of project that takes place in residential or protected areas. Figure 2-5 shows the basic structure of project evaluation.




Figure 2-5 The basic structure of the project evaluation process in transmission

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 21 of 103</i>
<i>Office: Long-term Planning and Development</i>		

During the project assessment process based on the ENTSO-E adopted methodology, there are various indicators classified as:

- *Benefit Indicators*
- *Project cost*
- *Environmental and social impacts*
- *GTC network transmission capacity*

There are seven **Benefit Indicators**, which are defined as follows:

**B1. Socioeconomic Wellbeing (SEW)** or market integration is characterized by the ability of the power system to reduce the aberrations and thereby ensure adequate grid transfer capacity (GTC) so that electricity can be traded (generated) in the most economical way.

**B2. The change in CO<sub>2</sub>** represents the reduction of CO<sub>2</sub> emissions in the power system due to the project. This reduction is due to the change in the distribute generators and the activation of the RES potential. The goal of CO<sub>2</sub> reduction explicitly represents one of the EU-20-20-20 targets and is therefore considered as a separate indicator.

**B3. Integration of RES**, namely the support for integration of RES is defined as the ability of the power system to enable the connection of new RES and activate existing and future RES, minimizing outages (Reductions) and electrical equipment produced by RES integration. Integration of RES is one of the goals of EU-20-20-20.

**B4 changes to social welfare**, as a result of CO<sub>2</sub> reduction and RES integration, there is an increase to social welfare beyond the economic effects that are identified during the assessment of the B1 indicator. The CO<sub>2</sub> emission reduction and RES integration into the electricity system because of the project is partially attributed to indicator B1 (SEW). The CO<sub>2</sub> emission reduction and RES integration results in the change of variable generation and emission costs (e.g. carbon tax) thus affecting in the increase of system costs. However, this may very well not reflect the entire social welfare having more RES in the system or in the total social cost of CO<sub>2</sub> emission (damage caused by the emission of ton of CO<sub>2</sub> will not necessarily reflect on the emission certificate costs which manufactures must pay). These additional effects are reported in this indicator.

**B5 Change in transmission network losses** represents the cost of compensating thermal losses (Joule losses) in the energy system because of the project. Otherwise, this represents an energy efficiency indicator expressed as cost in Euro per year.

**B6 Security of Supply: Adequacy of demand supply** characterizes the project's impact in the ability of the electricity system to provide sufficient supply of electricity to fulfil the demand for prolonged period of time. The effects of climate changes and production from RES is taken into account.

**B7 Security of Supply: System flexibility**: characterizes the project impact on the power system's ability to accommodate rapid and deep changes of (net) demand in the context of introduction at a high level of non-dispatchable electric generators.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 22 of 103</i>
<i>Office: Long-term Planning and Development</i>		

**B8 Security of Supply: System stability:** characterizes the project impact on the system stability to provide secure power supply according to the technical criteria defined in the Grid Code (Criterion N and Criterion N-1/power flow, short circuits, transient stability, voltages stability).

Other project impacts are defined as:

**The project's impact on society** is defined as:

**S.1 Environmental impact** represents the project impact as assessed by preliminary study, and aims to provide a project-related environmental sensitivity meter.

The environmental impact is related to the local impact of the project on nature and biodiversity, as assessed through preliminary studies. It is expressed in terms of how many kilometres of overhead or underwater/underground lines can pass through a sensitive environmental area (urban areas, protected areas, archaeological areas, national parks etc.).

**S.2 Social impact** represents the project's impact in the local population affected by the project as assessed through the preliminary studies, and aims to provide a measure of social sensitivity related to the project.

S3 Other impacts represent the indicator that will include all possible project impacts.

These three indicators refer to the remaining impacts, after the implementation of measures to minimize impacts. Therefore impacts which are minimized due to additional measures should not be presented in this category.

Project cost is defined as:

**C1. Capital Cost (CAPEX).** This indicator shows the value of investment for project implementation, which contains elements such as: costs of obtaining permits, for conducting feasibility studies, expropriation, for the construction parcel, for pre-preparation, design, equipment and materials and installation or dismantling. The project's capital cost is estimated by comparing it to similar projects implemented, and based on parameters from public information concerning similar project costs. CAPEX is expressed in EUR

**C2. Operational Cost (OPEX).** These costs are based on the project operational and maintenance cost. The operational cost of all projects should be estimated based on the current cost values and distributed per years expressed in EUR per year.

**Grid Transfer Capability (GTC)** is defined as:

**GTC** represents the network's ability to transmit electricity from an area to another. The interconnection of two areas represents a bottleneck in the energy system where the transmission capacity is insufficient to accommodate possible power flows (resulting from the scenarios). For the internal part of the network, the GTC may be affected by new lines as well as additional transformers installed in existing substations or new substations. In the new interconnection lines, GTC over 500 MW, in fact, represents a significant

regional impact of the new line, as defined by ENTSO-E. Mainly 400 kV lines can affect the upgrading of the GTC to 500MW.

### 3. ELECTRICITY GENERATION AND LOAD FORECAST

#### 3.1. Introduction

One of the basic data determining future transmission capacity development is to forecast electricity load or power. The load forecast represents an integral part of network planning, generation and transmission and distribution system operation. The main source of data for development of load forecast in the next 10 years is the demand forecast model developed by KOSTT, used by the document: Long-Term Energy Balance 2018 - 2027. This model represents a 10-year forecast, hour by hour, of the electricity demand. As such, this model enables the prediction of load, hour by hour, for the next 10 years, including peak loads (winter and summer).

#### 3.2. Historical information of the load, and current situation

The historical chart of maximum load development in our country is shown in Figure 3-1. Unusual characteristics of the load curve over the years reflects the political and socio-economic conditions in which our country has passed in the last three decades. The maximum load value recorded so far is the load of 2019 (December) which has reached the value of 1260 MW.




Figure 3-1 Peak load history over years in Kosovo

During 2017 ERO has changed the tariff system and this is expected to have a small impact on the increase of the load during the winter season.

The table 3-1 shows maximum loads registered for years 2004-2019, for winter and summer seasons.

Tab. 3-1 Maximum active loads, summer and winter, for the period 2004-2019

Year		2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019
Winter Peak	MW	811	898	916	933	967	1072	1158	1150	1168	1101	1154	1129	1160	1161	1201	1260
Summer Peak	MW	569	617	637	690	764	795	810	798	815	799	775	774	764	744	751	805

### 3.3. Demand profile

Features of the load duration curves for Kosovo’s Electricity System has went through constant changes, both in terms of proportional growth but also in terms of load factor change. Figure 3-2 shows the load duration curve for the previous year 2016, as well as basic characteristics of load.

In figure 3-3 is presented load duration curve hour by hour for the year 2019.




Figure 3-2 System Load duration curve for the year 2019




Figure 3-3 The diagram hour by hour of annual loads carried out during 2019

The diagram of the maximum and minimum load change for 365 days of 2019 year is shown in Figure 3-4. The difference between the maximum and minimum value of daily consumption during 2019 has shifted in the range from 280 till 506 MW.




Figure 3-4 Diagram for maximum and minimum daily load for 2019

The weekly load diagram in the winter season, of a typical week of January and July of 2020 now realized is shown in Figure 3-5. There is a decrease in consumption over the weekend, which represents a change in consumer behavior from previous years.

Figure 3-6 shows the daily diagram of national consumption of electricity for a typical day of January 2020 and of July 220, which correspond to reference points according to ENTSO-E.




Figure 3-5 Weekly typical diagram of January and July 2020




Figure 3-6 Daily load diagram for the referent point (3-rd Wednesday, January 2020 and July 2020) according to ENTSO-E

Table 3-2 shows simultaneous maximum loads in 220 kV and 110 kV consumption dividends by distribution districts, the industry connected to the transmission network and losses in the transmission network for the current year 2020. System models in PSS/E which reflects the current situation is based on the data presented in Table 3-2.

Cumulative consumption by districts of which KEDS consists, the industry connected to the transmission network and losses in the transmission network is illustrated in Figure 3-7.




Figure 3-7 Maximum load by DSO districts, industry connected to the transmission network and losses in KOSTT

Table 3-2 Loads in distribution substations forecasted for 2020

Substation loads during simultaneous peak conditions - 2020				
Regions	Substations	Installed capacity [MVA]	Simultaneous peak	P(MW)
<b>PRISHTINA</b>	Prishtina 1	126		66.2
	Prishtina 2	134.5		60.0
	Prishtina 3	71.5		44.9
	Prishtina 5	80		32.0
	Dardania	80		20.7
	Prishtina 7	80		41.9
	Bardhi (Palaj)	120		27.3
	Drenasi	80		20.2
	Podujeva	80		46.0
	Kosova A+B	/		62.3
	<b>Total Prishtina</b>	<b>852</b>		<b>421.5</b>
<b>Ferizaj</b>	Ferizaj(Bibaj)	103		79.7
	Sharrri	/		1.2
	Lipjani	103		52.7
	<b>Total Ferizaj</b>	<b>206</b>		<b>133.6</b>
<b>MITROVICA</b>	Vallaq	94.5		64.0
	Ilirida	80		48.0
	Vushtrri1	31.5		0.0
	Vushtrri 2	63		37.3
	Skenderaj	71.5		18.9
<b>Total Mitrovica</b>	<b>340.5</b>		<b>168.2</b>	
<b>PEJA</b>	Peja1	71.5		36.0
	Peja2	63		32.1
	Deçani	91.5		22.6
	Burimi (istogu)	71.5		15.6
	Klina	31.5		18.6
<b>Total PEJA</b>	<b>329</b>		<b>124.9</b>	
<b>GJAKOVA</b>	Gjakova 1	40		24.0
	Rahoveci	63		46.6
	Gjakova 2	63		31.0
	<b>Total Gjakova</b>	<b>166</b>		<b>101.6</b>
<b>PRIZRENI</b>	Prizreni 1	103		69.8
	Prizreni3	63		37.0
	Theranda	63		32.2
	<b>Total Prizreni</b>	<b>229</b>		<b>139.0</b>
<b>GJILANI</b>	Gjilan 1	51.5		34.0
	Gjilani 5	31.5		16.6
	Vitia	51.5		23.0
	Berivojca	63		11.7
	<b>Total Gjilan</b>	<b>197.5</b>		<b>85.3</b>
<b>INDUSTRY</b>	FERONIKELI	320		49.0
	SHARR CEM	40		7.0
	TREPÇA	94.5		2.3
	Other	/		3.0
	<b>Total industry</b>	<b>454.5</b>		<b>61.3</b>
	Losses in KOSTT			<b>23.0</b>
	Total Capacity without Ind	<b>2320.0</b>		
<b>TOTAL PEAK (MW)</b>				<b>1258</b>

### 3.4. Maximum annual load forecast 2021 - 2030

Forecast of the electricity is based on the forecast described in the “Long-Term Energy Balance 2017-2026” which document is in accordance with the provisions made in the Energy Strategy 2017-2026 adding the year 2030 and updating the peak value for the previous year 2019 according to the measurements made.

Forecast of the development of electricity demand for the period 2021-2030 under three different growth scenarios is shown in Figure 3-8, and numeric data corresponding to Figure 3-8 are shown in Table 3-3.

The baseline scenario of load development is characterized by an annual average growth of around 1.38%. This load development scenario will be the key input in evaluating the operating performance of the transmission network.




Figure 3-8. Low base and high growth scenarios for the peak load (maximum load)

Table 3-3. Respective data of peak forecast, related to Figure3-8

Maximal Load	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
Low Peak [MW]	1154	1129	1160	1161	1201	1260	1180	1175	1174	1183	1182	1186	1186	1185	1195	1204	1214
Base Peak [MW]	1154	1129	1160	1161	1201	1260	1258	1244	1256	1264	1271	1278	1285	1289	1300	1304	1310
High Peak [MW]	1154	1129	1160	1161	1201	1260	1302	1318	1338	1353	1366	1381	1394	1405	1423	1428	1435

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 30 of 103</i>
<i>Office: Long-term Planning and Development</i>		

## **4. GENERATION CAPACITIES OF KOSOVO'S ELECTRICITY SYSTEM**

### **4.1 Introduction**

The power flows in the transmission network are affected by the distribution of system loads, generation capacity and location and the power balance linking to the interconnection network depending on the level of imports or exports. The changes to the generation capacity, along with new capacity development and decommissioning of generation have a greater impact on changing the power flows compared to the loads.

Construction of any type of generator requires the development of a transmission network that would allow the generator to be connected into the grid and create the path for injection of power produced in the electro-energetic system. If the power flows of the new generator do not affect the safety of the transmission network operation, such connection is considered to be a shallow connection and does not implicate additional investment in the transmission network. If the security of some parts of the network is affected as a result of the change of power flows caused by the new generation connection, in addition to the interconnection network, the transmission network should be reinforced wherever the overloads occur. This case is considered to be a profound connection and implicates additional investments to maintain the security of the transmission system.

The connection of new generators into the transmission network, particularly large-capacity generators, results with increased level of short circuits powers in parts of the grid close to the generation and may implicate additional investment in equipment for limiting power failures or changing disconnection facilities at risk.

The impact on future transmission network development will most certainly be attributed to the development of renewable sources. It would be more economical to connect RES with relatively low capacity (<10 MW) into the distribution network, if the network provides generation security and power evacuation. On the other hand, higher-capacity RES mostly apply for connection to 110 kV network. In this case a 110 kV network should be developed which enables the RES connection to the transmission network. RES connected to the distribution network directly affects the reduction of power flows in the transmission network as well as the reduction of network losses. This necessarily provides a better forecast of the RES capacity development and their geographic distribution so as to avoid unnecessary investments in the transmission network determined by the initial network operation conditions.

### **4.2 Current generation capacities in Kosovo**

The electricity produced in Kosovo is dominated by two relatively large power plants: TPP Kosovo A and TPP Kosovo B which participate with 94% in total electricity production in Kosovo.

Table 4-1 shows the latest relevant information to the units of the Kosovo A and B.

Table 4-1. Main features of TPP Kosovo A and Kosovo B generation units

TPP	Unit	Installed Capacity [MW]	Net Capacity [MW]	Available Capacity [MW]	In Operation	Decommission
<b>TPP KOSOVA A</b>	A3	200	176	120-130	1970	Q4 2023
	A4	200	176	120-130	1971	Q4 2023
	A5	210	185	120-135	1975	Q4 2023
<b>TPP KOSOVA B</b>	B1	339	305	200-260	1983	2040
	B2	339	305	200-260	1984	2040
<b>Total TPP</b>		<b>1288</b>	<b>1147</b>	<b>760-915</b>		

Table 4-2 shows existing capacities of hydro power plants in Kosovo connected to the transmission network, a part of which is categorized as renewable sources, whereas Table 4-3 shows the total capacity according to the type of renewable generation connected to the transmission grid, which currently is operational. Current net capital from renewable sources reaches 139 MW, which represents 10.8% of the total generation capacity in Kosovo.

Table 4-2. Main features of existing hydro-power plants of Kosovo connected to the 110 kV Transmission System (Q4 2020)

HPP	Unit	Installed Capacity (MW)	Net Capacity (MW)	In Operation
<b>HPP Ujmani</b>	G1	17.5	16	1981
	G2	17.5	16	1981
<b>Lumbardhi 1</b>	G1	4.04	4.00	57/2005
	G2	4.04	4.00	57/2005
<b>Lumbardhi 2</b>	G1	5.4	6.19	2018
<b>Belaja</b>	G1	5.29	5.00	2015
	G2	2.79	2.50	2015
<b>Deçani</b>	G1	6.66	6.50	2015
	G2	3.15	3.00	2015
<b>Total in Transmission</b>		<b>66.37</b>	<b>63.19</b>	

Table 4-3. The capacities of Kosovo's existing RES connected to the transmission network (Q4 2020)

RES	Type of RES	Installed Capacity [MW]	Point of connec. [kV]
WP KITKA	Wind	32.4 MW	110

Table 4-4. Capacities of Kosovo’s existing RES connected to the distribution network (Q4 2020)

RES	Installed Capacity [MW]
HPP	68.11
Solar	11.35
Wind	1.35
Total RES in DSO	80.81

### 4.3 Projection of the development of new generation capacities 2021 - 2030

Projection of electricity generation remains the main challenge in the process of transmission network planning, due to the high uncertainty of their realization. In the current year 2020, the process of revision of the energy strategy (2021-2030) has started, which will be in line with the National Plan for Climate and Energy, which is currently being worked on by the Government of the Republic of Kosovo, respectively by the group established within the Ministry of Economy and Environment in accordance with the requirements and recommendations of the Energy Community. These two documents will define Kosovo's objectives for the 5 key dimensions pre-defined by the European Community:

- ***Security of Supply***
- ***Market Integration***
- ***Energy Efficiency***
- ***Decarbonization of the economy***
- ***Research, innovation and competition***

The dimension of **security of supply** sets medium and long-term objectives and standards related to security of supply, including the development of diversification of energy sources, infrastructure, energy accumulation, response to demand, willingness to cope with limited or interrupted supply of one source of energy, and the construction of alternative internal sources. This dimension also includes projections or scenarios for the development of electricity sources. The new energy strategy 2021-2030 will define the developments within the conventional resources with lignite such as: the time of revitalization of two units of TPP Kosova B, the time of operation of TPP Kosova A which means the revitalization of some of its units, or decommissioning and replacement with new Power Plant. The process of exit from fossil resources is expected to be gradual and long-term (2030-2050), but this type of resource for Kosovo will be for a long period of time the main pillar of security of supply. Fossil energy sources will be gradually replaced by renewable sources, accompanied by the development of flexible units, energy storage facilities which will be necessary to enable the integration of RES in the system. A very influential factor in the diversification of energy sources will be the development of gas infrastructure. It is expected that in this 10-year period Kosovo will have fully or partially developed the gas transmission network and a part of the gas distribution network. The development of the gas system and infrastructure, especially the distribution network, will affect in reduction of the demand for electricity, mainly due to the use of gas for heating. The development of gas infrastructure provides opportunities in the development of flexible gas sources that will be used by KOSTT for secondary and tertiary regulation. On the other hand, the electrical component of the gas infrastructure enables the increase of the flexible capacities necessary for the increase of the regulating reserves of the electricity system. Also by the time the gas infrastructure upgrade is planned (2027-2028)

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 33 of 103</i>
<i>Office: Long-term Planning and Development</i>		

other options for upgrading system flexibility are being considered, such as rechargeable batteries which will be used for secondary adjustment needs, for which the needs are increasing year after year as a result of the integration of renewable sources from wind and sun.

The **energy market integration** dimension sets objectives related to market competition, market integration and mergers, the establishment of flexibility in the energy sector, including the development of short-term markets, competition in demand response services, and the use of smart technologies and intelligent networks.

Another very important dimension is efficient use of energy, which will help the energy sector in reducing energy demand.

The dimension of de-carbonation is related to the previous dimensions, and the main factor that enables this is the creation of conditions for the energy and electricity system for gradual integration of renewable sources and the improvement of energy efficiency.

All can be achieved if the country provides favourable conditions for young researchers, innovation and genuine competition. Human resources are the key to success.

#### **4.3.1 Developments in renewable sources**

Renewable Energy Sources (RES) represent an important source of energy available to Kosovo, with a still untapped potential. The use of such sources for energy production represents a long-term objective of achieving the country's energy policy objectives such as: supporting overall economic development; increasing security of energy supply, and environmental protection. For the purpose of encouraging the use of renewable energy sources, a feed-in tariff scheme for water, wind, and photovoltaic and biomass energy is in place in Kosovo. The goal of such a measure that encourages the use of RES is to meet the targets for RES 2020 as required by Directive 2009/28/EC, whose transposition and implementation is done under monitoring by the Energy Community Secretariat. Indicative targets and ways of support for the next period after 2020 are expected to be set by ERO.

The Transmission and Distribution System Operator play an important role on the promotion of Renewable Energy Sources. These two Operators are obliged by law to prioritize energy produced from renewable energy sources, according to standards specified in the Grid Code.

Investments made in the transmission infrastructure during the last decade have resulted with an efficient, reliable and significantly secure transmission grid. Such development has created favourable conditions for supporting integration of renewable sources into the transmission network. Taking into consideration Kosovo's capacities for renewable sources, the connection of such generators is expected to occur mainly in the 110 kV grids, which are well developed and distributed throughout the territory of the Republic of Kosovo.

KOSTT has developed a highly efficient procedure for reviewing Applications for Connection to the Transmission Network, thereby avoiding procedural delays affecting the timing of project implementation. In 2018 the wind park "Kitka" with an installed capacity of 32.4 MW was put in operation, which is connected to SS 110/10 kV Berivojce through a 110 kV line with a length of 14.7 km.

The following projects are in the process of construction:

- Wind power plant "Selaci 1, 2 and 3" with installed capacity 105 MW<sup>1</sup>
- HC Lepenci with capacity 9.92 MW

---

<sup>1</sup> The wind park "Selaci 1,2 and 3" is expected to be in operation next year in 2021.

A large number of applications for the construction of wind and solar energy parks have applied for connection to the transmission network. Until September 2020 in KOSTT are accepted the applications which are presented in Table 4-5:

Table 4-5. Capacities of RES applied for connection to the transmission network until 2020

Wind Parcs	Capacity [MW]	Solar	Capacity [MW]
PE Koznica	34.5	SP Bejta Comerc	9
PE Budakova 46 MW	46	SP Sferka Solar	21
PE Zatriqi 64.8 MW	64.8	SP Energy Bio Ranch	9
PE Kamenica 1 ,2 dhe 3	100	SP SEGE	150
PE Cicavica	116		
PE Mareci	31.2		
PE KITKA upgrade capacity	20		
<b>Total from Wind</b>	<b>412.5</b>	<b>Total solar</b>	<b>189</b>
<b>Total Wind+Solar (aplikation)</b>	<b>451.5 MW</b>		

KOSTT has studied the impacts that would result from the connection of the abovementioned projects and has determined the optimal configuration of their connection to the transmission network. Some of the projects have completed connection agreements and are in the list of pending approval from ERO. The transmission network has sufficient capacities to integrate renewable sources of all kinds; however the only problem for the System Operator remains the increase of systems regulatory reserve requirements, with particular emphasis on secondary and tertiary control reserves, due to the variable and highly unpredictable wind and solar sources. This problem will be solved with the flexible generation construction, such as reversible hydro power plants.

Also an important steps is the integration of small markets such as regional markets into an integrated regional market, where access to ancillary services will be easier, and the level of control reserves required will also be reduced. The first step will be to create a common market between Kosovo and Albania, while the second step will be integration into the regional market.

## 5. KOSOVO'S TRANSMISSION NETWORK DEVELOPMENT PROJECTS (2021-2030)

### 5.1 The incentive factors of the development plan

Kosovo's electrical industry and its development are based on the objectives of the National Energy Strategy, as well as essential or strategic objectives of the European Union. This focus sets out the context of capital investment carried out in Kosovo's transmission system and can be summarized as follows:

- *Security of supply*
- *Ensuring competitiveness and development of the national economy*
- *Ensure the long-term sustainability terms of national electricity supply.*

To achieve these strategic objectives, it is necessary to ensure continued investments in the development and maintenance of the transmission system. Specific factors conducive to investment in the transmission network infrastructure have been identified and can be described as follows:

- *Ensure adequate supply of the transmission network*
- *Promotion of market integration and transparency*
- *Promotion of renewable resources and complementary thermal coal resources.*

To achieve adequate electricity supply security; integration and further development of the market, integration of new generation capacities, is related to proper planning of the transmission system. As the demand for energy and the generation changes, namely since the regional transmission network becomes even more interconnected, or as new generation connects to the network, electric power flows on the transmission network also change. To accommodate these changes in the power flows it is often necessary to strengthen the transmission network, to maintain the level of safety, performance and efficiency of the transmission system.

## 5.2 Implemented projects 2007-2019

During 2007-2019, 246 M€ capital investments have been made in KSOTT. Total investments since after the war until now (October 2020) in the transmission network are around 300 M€. Essential investments have been made in strengthening the transmission and transforming capacities of the network, which constitute 49% of total investments. Investments have been made even in other categories of projects, as shown in Figure 5-1.

Based on all measurable performance indicators recorded in the last decade, continued investments in transmission system infrastructure; modernization of support systems; human resource development, have enabled in a higher continuous security and performance of the transmission system operation.




Figure 5-1

Figure 5-2 shows the chart of capital investments distribution for the period 2008-2019, broken-down by relevant project categories.




Figure 5-2. Distribution of investments through the years according to projects category

A complete list of realized projects from 2007 until now is presented in Table 5-1.

Unlike the previous plan 2020 -2029 three important projects of the category for load support have been implemented: SS Ilirida 110/10(20) kV in Mitrovica, SS Drenasi 220/10(20) kV in Drenas and SS Dardania, 110/10(20) kV in the centre of Prishtina.

Table 5-1. List of realized projects in KOSTT from 2007 until Q4 2020.

No	LIST OF IMPLEMENTED PROJECTS 2007-2020 Project title	Year
1	Conductor replacement in the 110 kV line No. 125, SS Kosovo A - SS Vushtrri 1&2	2007
2	Conductor replacement in the 110 kV line No. 164/3, SS Prizreni 1 - SS Prizreni 2	2007
3	Replacement of 110 kV power switches in SS Prishtina 1 and SS Prishtina 2	2008
4	New 110 kV line - SS Prizren 2 - SS Rahoveci and SS Rahoveci	2008
5	Conductor replacement in the 110 kV line SS Deçan - SS Gjakova 1	2009
6	AT1 in SS Kosova A, 220/110 kV	2009
7	Revitalization of SS Kosovo A	2009
8	Revitalization of SS Prishtina 1	2009
9	Package project PEJA 3	2009
10	Replacement of relay protection facilities in SS Kosova B and SS Prishtina 4	2009
11	ITSMO meters (in borders)	2010
12	Adaptation of the L212 line as a 110 kV line SS Kosovo A - SS Ferizaj 1	2010

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 37 of 103</i>
<i>Office: Long-term Planning and Development</i>		

13	New 110 kV line SS Peja 3 - SS Klina, under the Peja 3 package project	2010
14	Connection of SS Skenderaj, with a dual 110 kV line, to the Vallaq - Peja 3 line	2010
15	AT3 in SS Prishtina 4, 220/110 kV	2010
16	Replacement of the conductor in the 110 kV line, L 126/5, SS Peja 1 - SS Peja 2	2010
17	Revitalization of SS Kosovo B	2011
18	Package Project FERIZAJ 2	2011
19	SCADA/EMS	2011
20	Package project SS Palaj with 110 kV lines	2011
21	Revitalization of SS Prizreni 2, 220/110 kV & AT3=150MVA	2012
22	Package project SS Gjilani 5 with transmission lines	2012
23	IT system supporting market operation	2012
24	Replacement of relay protection facilities in SS Prishtina 2 and SS Prishtina 3	2012
25	400 kV switches for generation fields in SS Kosova B	2012
26	Division of bus bars in two sections in SS Gjilani 1 and SS Theranda	2012
27	Rehabilitation of equipment for own-use in SS Kosova B	2012
28	General overhaul of 110 kV equipment in SS Prishtina 3 (GIS system)	2012
29	Rehabilitation of HV facilities in SS Ferizaji 1 and Gjilani 1	2013
30	Interconnection of SS Lipjan in the 110 kV L112 line	2013
31	Installation of two fields for 110 kV lines in SS Prizreni 2	2013
32	Replacement of conductors and izololatorëve. at 110 kV lines L125 / 2 and 125/3	2013
33	OPGW in 400 kV lines, SS Peja 3- SS Ribarevina, SS Ferizaj 2- SS Shkupi 5	2014
34	OPGW in 220 kV lines, SS Podujeva- SS Krushevc,	2014
35	Line allocation L1806 from SS Gjakova 2 to SS Gjakova 1 and re-vitalization of SS Gjakova 2	2015
36	Transformer installation 40 MVA, 110/10(20) kV in Skenderaj and Burimi	2016
37	Re-vitalization of HV equipments in SS Prizreni 3	2016
38	Re-vitalization of HV equipments in SS Gjakova 2	2016
39	LFC – Secondary Regulation	2016
40	Installation of 31.5 MVA transformers, in Berivojce and Viti	2016
41	Interconnection lines 400 kV SS Kosova B – SS Tirana 2 (242 km)	2016
42	Re-vitalization of MV (35kV) in SS gjakova 1	2016
43	Installation of third transformer 40 MVA, 110/10(20) kV in SS Prishtina 2	2016
44	Second transformer 300 MVA in SS Ferizaj 2 and Peja 3	2016
45	New 110 kV line SS Peja 3 - SS Peja 1 and revitalization of SS Peja 1	2016
46	Re-vitalization of SS Peja 1 (New GIS System)	2016
47	Revitalization of the 110 kV line: L126 / 2 SS Peja 2- SS Deçan	2017
48	Re-vitalization of TM (35 kV) equipment in NS SS Gjilani 1 and SS Ferizaj 1	2017
49	Revitalization of line fields and transf. 110 kV in: SS Lipjan and NS Viti	2017
50	INTER-OST Meters - Installation of metering points in cross-border lines	2017

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 38 of 103</i>
<i>Office: Long-term Planning and Development</i>		

51	Replacement of circuit breakers and separators in SS Prishtina 4	2017
52	Third transformer 40 MVA in SS Lipjan	2017
53	New Independent and Self Redundant AC/DC Supply System of SS/HV	2017
54	Re-vitalization of SCMS / SCADA in SS Kosovo B, SS Podujeva, SS Prishtina 5	2017
55	Implementation of changes in SCADA / EMS (Observation Area)	2017
56	Re-vitalization of HV equipment in SS Theranda	2018
57	Installation of metering groups at the new boundary between KOSTT and KEDS/DSO	2018
58	SS Ilirida, 2x40 MVA, 110/10(20) kV	2019
59	SS Drenasi, 2x40 MVA, 220/10(20) kV	2019
60	SS Dardania, 2x40 MVA, 110/10(20) kV	2019
61	New Line 110 kV SS Rahoveci – SS Theranda	2020

### 5.3 Transmission network infrastructure development 2021-2030

#### 5.3.1 Introduction

This chapter presents and examines transmission network development projects in the period 2021-2030. These projects were also presented in the previous 2020-2029 plan, with the inclusion of changes that belongs mainly in implementation times, but also design change and priority. Considering that the planning process of the transmission network is an extremely complex process, greatly dependent on many factors, the ten-year period that defines this document is divided into two periods:

**The first period of five years 2021-2025**, which is considered relevant and influential in the long term development of the network, with high probability of implementation. Projects included in this period of time are analyzed in detail. This timeline of the plan is linked to the 5 year investment plan 2018 – 2023 which is approved by the ERO.

**The second five years period, 2026-2030**, includes optional (indicative) projects of internal or regional character for which **KOSTT** considers their importance and their contribution in achieving the technical standards for operation of the transmission system in order to support the electricity market. This category of projects may be subject to change depending on processes that take place in the energy sector in Kosovo and the region. Generally, this relates to the development of generation and load as well as power flows expected to occur in the next decade in the regional network.

Transmission network development projects are divided into five categories:

- **Transmission network reinforcements**
- **Load support/New 110/10(20) kV nodes**
- **Rehabilitation of the transmission network**
- **Supporting projects of the transmission system (management, monitoring, measurement and control),**
- **Generation support (Connection application)**

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 39 of 103</i>
<i>Office: Long-term Planning and Development</i>		

Because of considerable complex dependence on the various factors for the implementation of the projects, the time and manner of such implementation can be considered as subject to possible changes and as such the next document will revise the data and update them.

Tables contain the project identification codes (ID), a general description of the project, the expected completion time and reasons and effects of project implementation.

### 5.3.2 List of new development projects planned for the period 2021-2030

The following is a list of planned projects broken down by categories, which are the result of optimal selection of different scenarios to strengthen the network during the planning process. These projects include the period 2021-2025. Lists of projects are presented in tables categorized according to the respective specifications. Factors considered influential in the redesign of some previously planned projects, in the change of timelines of their implementation and selection of certain new projects, are processes that are not dependent on **KOSTT**, such as:

- *Requests for new connections of load or generation*
- *Provision of funding*
- *Issues with of expropriation of property, substations and line routes etc.*
- *Unforeseen problems during the procurement process*

For the reasons above, the planning process and selected projects for development are adjusted to new changes that occurred in the meantime.

#### 5.3.2.1 List of new projects in the category of transmission network reinforcement

The table 5-2 provides a list of projects planned for the next 10 years, which are considered to be influential in building network capacities, pursuant to technical requirements obliged from the Grid Code. Projects are ranked according to their planned implementation period.

The following tables 5-2, 5-3 and 5-4 show projects under implementation, grouped by category.

**Tab. 5-2 Tabela 5-2 Lista e projekteve të planifikuara për përforcimin në rrjetin e transmetimit 2021-2030**

PROJECT CATEGORY: TRANSMISSION NETWORK REINFORCEMENT - (2021-2030)					
No	ID	Project title	Technical description	Reason for implementation	Year
1	010/2	<b>Variable reactor 100MVAR, 400 kV in SS Ferizaj 2</b>	- Installation of variable reactor 100MVAR in the free field 400 kV C05 in SS Ferizaj 2 - Reactor field 400 kV	Reducing overvoltage level in the transmission network. Regionally coordinated project	Q4-2022

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 40 of 103</i>
<i>Office: Long-term Planning and Development</i>		

2	010	<b>Second 40 MVA transformer in SS 110/10(20) - Klina</b>	TR2 Transformer 1 110/10(20) kV, 40 MVA - - 1 transformation field 110 kV and 10(20) kV completed	Security of supply consumption of Klina, maintenance and optimization of SS. Increase of transformation capacities	Q2-2025
3	012	<b>Revitalization of 110 kV line: SS Prizren 1 - SS Prizren 3</b>	- Replacement of the conductor from 150/25mm <sup>2</sup> to HW 170 mm <sup>2</sup> , 4.69 km in length from SS Prizren 1 to SS Prizren 3. The conductor is taken from the Prizren 1- Prizren 2 line, which will be demolished and turned into double line	Increased transmission capacities of the line from 83 MVA to 114 MVA, with the aim of increasing the transmission capacity and fulfilling the N-1 criterion.	Q2-2025
4	013	<b>New 110 kV line SS Prizren 1 - SS Prizren 2</b>	- 4.81km, Al/St 240 mm <sup>2</sup> , dismantling the existing and using the tracks. In addition, the current HW 170 mm <sup>2</sup> conductor is used for strengthening the Prizren1-Prizren 3 capacity line. - Field of the 110 kV line in SS Prizren 2, - Field of the 110 kV line in SS Prizren 1	The construction of new transmission line that enables the fulfilment of N-1 criterion and reduces network losses	Q2-2025
5	014	<b>Second 40MVA transformer in SS 110/10 (20) kV Gjilan 5</b>	Transformer TR2 110/10 (20) kV, 40 MVA - 110 kV transformer field and 10 (20) kV	Security of supply consumption of Gjilan, maintenance and optimization of SS. Increase of transformer capacities.	Q4-2025
6	015	<b>Replacement of the transformer in 110/10kV SS Deçan, (40MVA)</b>	-New Transformer 110/10(20) kV, 40 MVA replaces transformer TR1: 20 MVA, 110/10kV (1970 year)	Security of supply consumption of Deçan; Reducing power losses in distribution.	Q4-2025
7	016	<b>Replacement of the transformer in SS 110/10 kV Gjakova 1 (40MVA)</b>	-TR2 transformer 20 MVA, 110/35 kV (1965 year) replaced with 40/40/40 MVA (in coordination with KEDS) - A transformation field 10(20) kV	Security of supply consumption Gjakova; Reducing power losses in distribution.	Q2-2025
8	023	<b>Replacement of the transformer in 110/10 kV SS Theranda, 40MVA)</b>	-New Transformer 40 MVA 110/10(20) kV replace transformer TR2: 31.5 MVA, 110/10 kV(1985 year)	Security of supply consumption of Theranda; Fulfilment of N-1 transformation criteria. Reducing power losses in distribution.	Q4-2025
9	050	<b>Replacement of the transformer in SS Ferizaj 1, (40MVA)</b>	-Replacement of TR2 31.5MVA (year 1969), 110/35kV with the new three-pole transformer 40/40/40MVA, 110/35/10(20)kV - A transformer field 10(20) kV	The project avoids potential high probability breakdown of the old transformer and enables the fulfilment of the N-1 transformation criteria at the 10 kV level	Q4-2025
10	051	<b>Re-construction of 110 kV line: SS Palaj-SS Ilirida- SS Vallaq (segment 150 mm<sup>2</sup>)</b>	- Dismantling of the existing 150mm <sup>2</sup> section line, 37.18km from SS Palaj to Vallaq (150mm <sup>2</sup> section segment, 1958 year); - Construction of new line 37.18 km ALSt, 240 mm <sup>2</sup>	Increase of transmission line capacity from 83 MVA to 114 MVA, reduction of power losses, fulfilment of N-1 security criterion for 110 kV network	Q1- 2026

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 41 of 103</i>
<i>Office: Long-term Planning and Development</i>		

11	053	<b>Replacement of transformer in SS Prizreni 1 and SS Peja 1 (40MVA)</b>	<ul style="list-style-type: none"> <li>- In Prizren 1, TR1 31.5MVA(year 1975),110/35kV will be replaced with 40/40/40MVA transformer, 110/35/10(20)kV -</li> <li>In SS Peja 1, TR1 31.5MVA (y1985),110/35kV will be replaced with 40/40/40MVA, 110/35/10(20)kV</li> <li>- Two transformer fields 10(20) kV</li> </ul>	<p>The project avoids potential high probability breakdown of the old transformer and enables the fulfilment of the N-1 transformation criteria even at the 10 kV level.</p>	Q1-2026
12	055	<b>New 110 kV cable line SS Prishtina 2 - SS Prishtina 4</b>	<ul style="list-style-type: none"> <li>- Two fields of 110 kV lines</li> <li>- 1000mm<sup>2</sup> cable line, about 4.85 km long</li> </ul>	<p>The project enables the fulfilment of N-1 criterion for the 110 kV network part connecting SS Prishtina 2 &amp; 3 and SS Kosova A</p>	Q2-2026
13	052	<b>Revitalization of 110 kV line: L116 (155/2) Vallaq border</b>	<ul style="list-style-type: none"> <li>- Replacement of phase conductors and protection one to the border (18.78 km in length). Year 1958</li> <li>- Enforcement of pillars and replacement of isolators.</li> </ul>	<p>Enforcement of transmission capacities and support to load management for the northern part of Kosovo</p>	Q4-2027
14	059	<b>Replacement of transformer in SS Gjakova 1, Gjilani 1 and SS Vitia (40MVA)</b>	<ul style="list-style-type: none"> <li>- In Gjakova 1, TR1 20MVA (year 1974) is replaced with 40MVA transformer, 110/10 (20) kV</li> <li>- In Gjilani 1, TR1 31.5MVA(year 1974), 110/35kV is replaced with 40/40/40MVA, 110/35/10(20)kV</li> <li>- In Vitia, TR1 20MVA (year 1974) is replaced with 40MVA transformer, 110/35/10(20) kV</li> <li>- Two 10(20) kV transformer fields</li> </ul>	<p>Increase of the supply security for consumer in Gjakova, Gjilan and Viti</p>	Q4-2027
15	060	<b>Revitalization of the 110 kV line: L127 SS Bibaj - SS Kastriot (new SS)</b>	<ul style="list-style-type: none"> <li>- Dismantling of the existing 150mm<sup>2</sup>section line from SS Bibaj (Ferizaj 1) to SS Kastrioti (Ferizaj 3) connection point, 6.7 km long</li> <li>- Construction of new 6.7 km ASCR line, 240 mm<sup>2</sup></li> </ul>	<p>Increase of transmission line capacity from 83 MVA to 114 MVA, reduction of power losses in 110 kV network</p>	Q4-2028
16	061	<b>Revitalization of the 110 kV line: L106 SS Ferizaj 2- SS Sharr</b>	<ul style="list-style-type: none"> <li>- Dismantling of the existing 150mm<sup>2</sup> section line, 28.7 km from SS Ferizaj 2 to SS Sharr (150mm<sup>2</sup> section segment, year 1953);</li> <li>- Construction of new 28.7 km</li> <li>- ASCR line, 240 mm<sup>2</sup></li> </ul>	<p>Increase of transmission line capacity from 83 MVA to 114 MVA, reduction of power losses in 110 kV network</p>	Q4-2029

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 42 of 103</i>
<i>Office: Long-term Planning and Development</i>		

17	054	<b>SS NASHEC, 400/220/110 kV with interconnection line 400 kV</b>	<ul style="list-style-type: none"> <li>- Construction of SS Nashec, 400/110 kV, 1x300MVA, as a continuation of SS Prizreni 2, which comprises two 400 kV line fields and one 400 kV connection field, one 400 kV TR field and one 110 kV TR field.</li> <li>- Expansion of the 110 kV busbar system</li> <li>- Construction of the 400 kV double line, 26 km in length from the cutting point of the 400 kV Kosova B-Koman</li> </ul>	<p>Configuration of the 400 kV and 110 kV grid and optimize of active and reactive power flows, reduction of losses, and support of new generation and load. Creating conditions for the second 400 kV interconnection with Albania</p>	Q4-2030
----	-----	---	---	---	---------

**Remark: The blue-font ID projects represent projects beyond the 5-year Investment Plan 2018-2022, the red-font ID projects represent new projects in the Investment Plan 2018-2022 and green-font ID projects represent new projects that are different from the Development Plan 2019-2028**

### 5.3.2.2 List of new projects in the category: Load support

The inclusion in the plan of investments in 110/TM substations will be confirmed when companies, KOSTT and KEDS, harmonize their respective development plans. Main signals that would initiate the construction of a new SS 110/TM come from KEDS and are based on demand development data in the long-term domain. Also, another initiating signal could be the level of transformer loads in existing substations managed by KOSTT. Whenever security of supply is put in danger and there are no possibilities to install additional transformers, the development of a new substation for that area will be initiated, in a harmonized effort with KEDS. In such circumstances, KEDS, after harmonizing the project, commits to the provision of investments in distribution network infrastructure 35 kV, 10(20) kV which will be installed in the 110/TM substation.

Table 5-3 shows load support projects (new substations) envisaged for the forthcoming ten years:

Table 5-3 List of projects planned for load support 2021 – 2030

PROJECT CATEGORY: LOAD SUPPORT - - (2021-2030)					
Nr	ID	Project title	Technical description	Reason for implementation	Year
1	004	<b>SS 110/35/10(20) kV - Fushë Kosova<sup>2</sup></b>	<ul style="list-style-type: none"> <li>- GIS type substation 110/35/10(20)kV 2x40 MVA with two 110 kV transformer fields and 35 kV, 10 (20) kV, with two 110 kV line fields, with a 110 kV connection field</li> <li>- Command centre with ancillary equipment</li> </ul>	<ul style="list-style-type: none"> <li>- Increased security of supply, reduction of losses in the distribution network, optimum distribution of power flows in the 110 kV lines and transformers.</li> </ul>	Q3-2022
2	004/2	<b>SS 110/10(20) kV Kastrioti (Ferizaj 3) with 110 kV transmission lines</b>	<ul style="list-style-type: none"> <li>- 110 kV dual line with 3.1 km length, AlSt 240 mm<sup>2</sup> and 0.3 km 1000mm<sup>2</sup> double cable from SS Kastrioti (Ferizaj 3) to the connection point in 110 kV line SS Theranda-NS Bibaj (Ferizaj 1)</li> <li>- Transformer 1x40 MVA, 110/10(20) kV</li> <li>- One 110 kV and 35kV, 10(20) kV transformation field, and two line fields and one 110 kV connection field.</li> <li>- Command centre with ancillary equipment</li> </ul>	<ul style="list-style-type: none"> <li>- Increasing the safety and quality of Ferizaj consumption supply. Transformer discharge in SS Bibaj and fulfilling of N-1 transformation criterion</li> </ul>	Q3-2022
3	011	<b>SS Malisheva 220/10(20) kV with 220 kV transmission lines</b>	<ul style="list-style-type: none"> <li>- 250 m dual line 220 kV, Al/St 490 mm<sup>2</sup> from SS Malisheva to the connection point in the line 220 kV SS Drenasi - SS Prizreni 2</li> <li>- Transformer 2x40 MVA, one with 220/35/10(20) kV and the other 220/10(20) kV</li> <li>- Two 220 kV and 35 kV, 10(20) kV transformation fields, two line fields and one 220 kV, 1 bay field of 220 kV</li> <li>- Command facility with ancillary equipment</li> </ul>	<ul style="list-style-type: none"> <li>- Increasing security and quality of consumer supply to the Malisheva region. Reducing of power flows in SS Rahovec</li> </ul>	Q3-2022
4	009	<b>SS 110/10(20) kV Dragash with 110kV transmission lines</b>	<ul style="list-style-type: none"> <li>- SS Dragashi, 2 110 kV transformation fields, one 10(20) kV and one 35 kV, two line fields and one 110 kV connection field.</li> <li>- Single lines, 8 km, AlSt240 mm<sup>2</sup> from SS Prizreni 2 to Zhur (double poles)).</li> <li>- Double lines, 13 km, AlSt2x240 mm<sup>2</sup></li> <li>- From Zhuri to SS Dragash</li> <li>- Single line, 26 km, Al.Çe240 mm<sup>2</sup> from Zhuri to Kukës (from Zhuri to the border, 9 km))</li> </ul>	<ul style="list-style-type: none"> <li>- Qualitative and reliable supply of the Dragash region. Reduction of power flows in SS Prizren 1. Optimization of operation of systems of Kosovo and Albania</li> </ul>	Q4-2025

<sup>2</sup> Supply lines / cables of SS Fushë Kosova are built in the framework of EBRD projects.

### 5.3.2.3 Projects planned for the category: Re-vitalization of KOSTT substations

The following table contains a list of projects related to the process of revitalization of substations managed by KOSTT.

Table. 5-4. List of projects of the category of re-vitalization of substations 2021-2030

PROJECTS OF CATEGORY: REVITALIZATION OF SS (KOSTT)- (2021-2030)					
Nr	ID	Title of Project	Technical Description	Reason for development	Year
1	017	<b>Revitalization of HV equipment in SS Klina and SS Burimi</b>	<ul style="list-style-type: none"> <li>- Replacement of 3 line fields 110 kV,</li> <li>- Replacement of 2 transformer fields 110 kV (In SS Klina must first be installed the second transformer, and then the field should be changed)</li> </ul>	To increase the security and reliability of substation's operation	Q4-2025
2	022	<b>Revitalization of HV equipment in SS Vallaqi</b>	<ul style="list-style-type: none"> <li>- Replacement of five field lines 110 kV, replacement of two transformer fields 110 kV.</li> <li>- Replacement of busbar systems 110 kV and portals and construction of a new connection field 110 kV..</li> </ul>	Safety and reliability of supply, expiry of equipment lifespan. Increasing the work safety of HC Ujmani	Q2-2026

### 5.3.2.4 Projects planned in the category: Supporting transmission system operation

The following table presents the projects planned in the category of supporting transmission system operation. This list was selected through an identification of transmission system in complying with technical requirements emerging from the Grid Code and technical requirements recommended by ENTSO/E.

Table 5-5. List of projects in the category of support to system operation 2021-2030

PROJECTS OF CATEGORY: Support of the transmission system (2021-2030)					
Nr	ID	Project title	Technical description	Reason for development	Year
1	025	<b>Marking overhead lines for aviation safety</b>	Placing visual signs on overhead lines in areas of national interest: <ul style="list-style-type: none"> <li>-placement of signalling balls</li> <li>-Flashing lights</li> <li>-Painting of the pillars (white-red)</li> </ul>	The project fulfils the statutory obligation regarding signalling on specific areas of national interest in terms of aviation flights safety.	Q2-2020-Q2-2024

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 45 of 103</i>
<i>Office: Long-term Planning and Development</i>		

2	029	<b>Upgrade of SCADA/EM</b>	<ul style="list-style-type: none"> <li>-Operationalization of the SCADA/EMS platform at the National Dispatch Centre and the Emergency Dispatch Centre</li> <li>-Operationalization of the Market IT platform</li> </ul>	<ul style="list-style-type: none"> <li>- Fulfilment of new ENTSO-E criteria. Increase the performance of the transmission system command and control centre and the management of the Electricity Market</li> </ul>	Q4-2022
3	034	<b>Migration toward advanced telecommunication systems</b>	<ul style="list-style-type: none"> <li>-Increase bandwidth capacity: - Network segmentation, for various services and applications</li> <li>-Application quality,</li> <li>-Redundance and network protection</li> <li>- Limiting losses, delays for critical time applications.</li> </ul>	<ul style="list-style-type: none"> <li>- Bandwidth: to fulfil requirements for broadband, namely increased communication speed for applying video surveillance etc.</li> <li>- Network segmentation, for various services and applications</li> <li>- Quality of application, namely setting the appropriate priority and network performance for individual applications</li> <li>- Redundancy and network protection for most necessary and required applications. For most applications, outages for activating the spare route should not last more than 50ms, as is the case with SCADA.</li> <li>- Limitation of loss, delays for time critical applications. In some cases delays should be non-existent, such as applications that still use inherited PDH interfaces such as remote protection.</li> </ul>	Q4-2024

### 5.3.2.5 Generation support project categories

Over the past two years, KOSTT has received applications for connection from renewable sources mainly from wind and hydro power plants.

In the following table 5-6 are presented the projects that are being implemented and those for which the connection agreement on the transmission network has been signed. It does not mean that projects that already have a connection agreement that will be implemented based on previous experiences.

Tabela. 5-6. List of projects in the category of generation support 2021-2030

CATEGORY PROJECTS: GENERATION/RESs SUPPORT - (2021-2030)					
No	ID	Project title	Technical description of equipment for connection to the transmission network	Reason for Support and Statute	Viti
1	056	<b>PEE "SELACI 1,2 dhe 3 "</b> <b>105 MW, 30</b> <b>turbines x3.45MW:</b>	<ul style="list-style-type: none"> <li>-Line 110 kV, 240 mm<sup>2</sup>, 19.35 km, AlSt SS Vushtrria 1 – PEE "Selaci 1,2 &amp; 3"</li> <li>-2 110 kV lines field</li> </ul>	Supporting of RES integration into the Power System. A connection agreement has been signed.	Q4-2021

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 46 of 103</i>
<i>Office: Long-term Planning and Development</i>		

2	057	<b>HC "LEPENCI" 9.92 MW</b>	-110 kV double line, 240 mm <sup>2</sup> , 1.2 km, AlSt HPP "Lepenci"- Cutting point in 110 kV lines SS Ferizaj 2-SS Sharr -2 110 kV lines field	Supporting of RES integration into the Power System. A connection agreement has been signed..	Q4-2021
3	058	<b>PEE "KOZNICA" 34.5 MW 10 turbine x3.45 MW</b>	-110 kV double line, 240 mm <sup>2</sup> , 1.4 km, AlSt PEE "Koznica"- Cutting point in 110 kV line Prishtina 4 – Gjilani 1  -2 110 kV lines field	Supporting the integration of RES into the Power System. A connection agreement has been signed..	Q4-2022
4	062	<b>PEE ÇIÇAVICA 116 MW</b>	- 220 kV double line, 240 mm <sup>2</sup> , 0.2 km, AlSt -PEE "Çiçavica"- Cutting point in 220 kV line Kosova B – SS Drenas -2 field lines 220 kV	Support of RES integration into the Power System. The connection agreement has been signed	Q4-2022
5	020	<b>Installation of solar panels and power efficiency at KOSTT substations</b>	- Installation of solar panels in the roofs of SS facilities (total 1000 kW) and electrical systems for connection to 0.4 kV substations - Increasing the efficiency of KOSTT's SS facilities	Efficiency and reduction of the costs of using electricity in substations.	Q2-2025

## 5.4 Technical description of transmission planned projects for the period 2021 -2030

### 5.4.1 Introduction

The following is a description of development projects from the list of projects planned for the period 2021-2030. This projection of the transmission network development creates the conditions for the development of new conventional and renewable generation capacities in the next 10 years. This time period includes projects which directly contribute to the strengthening of the transmission network, projects to revitalize substations, load support projects and Transmission System support projects.

### 5.4.2 Projects of category: Transmission grid strengthening

The following are detailed descriptions of planned projects pertaining to the category of strengthening or capacity increase of transmission network, for the planning period 2021-2030.

- **Projects (ID/010/1): Variable-Shunt reactor 100MVar, 400 kV in SS Ferizaj 2**

In the last three years there is an increase in the level of voltage in the horizontal network, mainly this increase is observed at the level of 400 kV and 220 kV. In some periods of time, especially during the summer system operation mode, the voltage level exceeds the maximum nominal values set by the Grid Code. This high voltage level creates great strain on the insulation of 400 kV voltage equipment, risking dangerous downtime of the busbar system and on the other hand affects in the reduction of the life of the equipment and increases the losses in the transformer cores (iron losses). Figure 5-3 can be seen the frequency of overvoltages ( $> U_{max} = 420kV$ ) measured in SS Peja 3. Year after year it is observed that the

hours of operation of the network in overvoltage conditions are increasing and are quite disturbing. Some drops of lines and busbars have been recorded during the last two years as a result of overvoltages and mainly appear in polluted and high humidity areas. The area around the Power Plants is characterized by the aforementioned conditions.




Figure 5-3. Frequency of occurrence of overvoltages in 400 kV busbars in SS Peja 3 during 2019

This problem cannot be solved isolated, by KOSTT alone, as it is a regional problem as a result of the construction of many 400 kV lines in the region and without reactive power compensation. On the other hand, the level of horizontal network load in the network of Southeast Europe has decreased as a result of the economic recession in the region. This problem appeared a few years ago in the horizontal network of Croatia, Bosnia and Herzegovina, whereas gradually expanded to the part close to our transmission network. The commissioning of new 400 kV lines in the region without adequate compensation, with low loading level has led to the appearance of excess capacitive reactive power which significantly increased the level of voltages. Based on the regional study entitled "Regional Feasibility Study for voltage profiles improvement in the Western Balkans" it has been identified that the regional network from the six countries of the Western Balkans (WB6) has a reactive power surplus of about 800 MVar. The distribution or contribution of each TSO to this reactive power surplus is presented in the following table:

Table 5.7 Reactive power surpluses for the six TSOs of the region

OST	CGES	KOSTT	NOS/EL.PRENOS	MEPSO	EMS	Total
0	207	75	327	143	42	794

The amount of 800 MVar is a minimum volume of reactive power compensation to be installed in the "WB6" region to maintain the voltage level below the allowable upper limit (420 kV). The required volume

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 48 of 103</i>
<i>Office: Long-term Planning and Development</i>		

of reactive power compensation for the existing state of the system, based on the optimal power flow results according to the study is about 950 MVAR, respecting the target voltage range at 400 kV in the range from 1.05 pu (420 kV) - 1.03 pu (412 kV). This volume should allow the necessary safety margin for voltage control system services.

According to the study by 2030, KOSTT should install reactive power reactors in the range from 120MVAR to 150MVAR, based on data from long-term regional models. Considering the uncertainties of the implementation of these plans and taking into account that the new generators must meet the technical conditions to support the reactive power system then initially KOSTT will install the 100MVAR variable reactor at the location recommended by the study. According to the information, Albania has installed a 120 MVAR reactor in the 220 kV network and the second 120MVAR reactor is expected to be installed soon in SS Elbasan. Also in the next two years it is expected that the Montenegro operator CGES will install the 250MVAR reactor in SS Lastva, due to the problems that are being faced by the converter substation in SS Lastva which connects the submarine cable with Italy. These projects will be essential to avoid critical overvoltages over 430 kV, while in order to stabilize the entire network of WB6 countries, 100 MVAR should be installed in SS Vranje (EMS), 220MVAR in SS Tuzla and 120MVAR in SS Mostar (NOS/EI.PRENOS) and 150MVAR in SS Dubrova and 100 MVAR in SS Ohrid (MEPSO).

The study recommends the installation of variable-shunt reactors (VSR) as they have advantages over shunt-reactors with fixed power.

Variable-shunt reactors (VSR) allow a continuous compensation of reactive power in the range from 20-100% of nominal capacity, with the application of voltage regulator, similar to power transformers. The adjustment speed is determined by the voltage regulator and can meet relatively slow load variations (seasonal, daily or hourly). Variable reactor control is usually performed by operators, through the SCADA system.

The use of VSR allows the reactive power compensation to be adjusted depending on the current load and to operate the network in an optimal way, thus reducing power losses and increasing the active power capacity of the lines. Other important benefits include:

- Connection of certain degrees of variable reactor capacity is manifested by smaller switching pulses compared to shunt reactors.
- If VSR operates in the low installed power range, losses and noise emissions are reduced,
- By adjusting the reactor inductance within the unit itself, the power switches will have fewer connections and disconnections and will require less maintenance,
- Provide flexibility to adapt to future load changes (in emerging economies with increasing demand, where the load will increase over time).

It should be noted that a VSR is a more cost-effective solution than two fixed reactors; it is less costly, requires less installation space, requires less equipment (only one switch) and allows a better adjustment of seasonal and daily load variations.

The project foresees:

- Installation of variable-shunt reactor, 400 kV with power of 100 MVAR in the free field C03 in SS Ferizaj 2 (figure 5-4)

- Installation of 400 kV reactor field




Figure 5-4. Single line scheme of installation of 100 MVar reactor in SS Ferizaj 2

Expected benefits from the project:

- Avoidance of overvoltages in the transmission network
- Reduction of overvoltages reduces the accelerated aging of high voltage equipment as a result of degradation of insulation in equipment
- Short connections in the busbars of the main substations in KOSTT are avoided, where the TPP Kosova B and TPP Kosova A generators are also affected.
- The number of short connections in the transmission network is reduced as a result of the blowout of insulation from overvoltages, and with this the energy not sent to the consumer
- The operations of TPP Kosova B and TPP Kosova A in the sub-excitation mode (reactive power absorption) are avoided and their stability is maintained.
- Reduction the Corona effect and the losses caused by this effect
- Reduction of reactive power flows in lines and increase of carrying capacity of lines for active power.

Due to its high importance, the project is considered a high priority. The project is planned to be energized in Q2-2022.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 50 of 103</i>
<i>Office: Long-term Planning and Development</i>		

- **Projects (ID/010 and 014): Additional transformers in SS Klina and SS Gjilani 5**

Substations SS Klina and SS Gjilani 5 currently operate with only one transformer. Operation with only one transformer is a major problem in case of an unplanned outage. There is no backup supply (ring network and the secondary voltage) in the areas where the aforementioned substations are located, which for such cases for a short time would transfer the supply from the failing network to the medium voltage network. Substations operating with only one transformer, hinder the process of periodic maintenance of the transformer and its field (110 kV, 35 kV or 10 kV). On the other hand substations operating with only one transformer, hinder the important process of periodic maintenance of the transformer and its field (110 kV, 35 kV or 10 kV). The probability of faults in the transformer and its fields is also impacted by age, power flows, and short circuits in the system, and previous level of maintenance. Many facilities or system components, including transformers and switchgear in 110/35 kV substations and 110/10 kV, are faced with severe constraints caused by breakdowns/shorts circuits in the 110 kV network, frequent in the period 1990-2006 when the network had insufficient transmission and transformation capacity. Breakdowns in transformers such as the winding, or voltage regulator are problematic, and their repair requires time and is sometimes not financially viable. The time from the moment of the breakdown occurs to its elimination, or replacement of transformer can take days, thus the damage causes to customers will be greater in the absence of a second transformer, or a reserve capacity to supply from the medium voltage network. The amount of undelivered energy will be very significant, with negative socio-economic effects for consumers.

To avoid the risk of not supplying the consumer as a result of losses/disconnection of the transformer it is necessary to install the second transformer in the substations above.

- In SS Klina in **2022** is planned the installation of a second transformer 40 MVA, 110/10 (20) kV in addition to the existing transformer 31.5 MVA, 110/10 kV. Also will be installed respective 110 kV and 10 (20) kV transformer fields. This project will create conditions for the fulfillment of N-1 transformation. This project should be synchronized with the revitalization project of the 2 existing 110 kV fields, so that the undelivered energy to consumers during the project implementation process is minimized.
- In SS Gjilan 5 in **2022** is planned to install a new transformer 40 MVA, 110/10 (20) kV, in addition to the existing 31.5 MVA, 110/10 (20) kV, and two respective fields 110 kV and 10 (20) kV. This project will create conditions for the fulfillment of N-1 transformation.

Expected benefits from three these projects are:

- *Reduction of undelivered power to consumers of Klina and Gjilan region,*
- *Increased safety and reliability of load supply of distribution consumption*
- *Support for further development of the distribution network 10 (20) kV*
- *Increased of 110/MV kV transformation capacities and fulfillment of the N-1 in transformation*
- *Optimization of maintenance processes.*
- *Support to the development of the economic sector/industrial load.*

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 51 of 103</i>
<i>Office: Long-term Planning and Development</i>		

▪ **Projects (ID/015 and 016): Replacement of transformers at SS Deçani, SS Gjakova 1**

Second existing transformer 20 MVA in SS 110/10 kV Deçan has been constructed in 1977, which implies current age of 42 years. Maximum lifespan for transformers which on average are loaded above 60% value is considered to be 40 years. This life cycle may be shorter, depending on the number of overloads in transformer and faults in network. The chemical analysis and electrical parameters analysis carried out by the maintenance teams indicate an inadequate transformer state and, as such, it is estimated that this transformer can be operational for the next two years with a more pronounced supervision. To avoid the problem of dangerous damages that may appear later, it is necessary to replace this transformer with a new transformer with higher capacity of 40 MVA, 110/10(20) kV. The project increases the security of supply, substation and staff operating the transformer. The project is expected to be in operation in **2025**.

The first existing transformer in SS Gjakova 1 with a 20 MVA capacity, 110/35 kV was built in 1965, being 54 years old. In principle, its normal life expectancy has been exceeded and, as such, based on the evaluation of maintenance teams, it can be operational for the next two years and in 2025, it should be replaced with a new 110/35/10 (20) kV three-pole transformer with 40/40/40 MVA capacity for all three poles, so that part of the 35 kV network in the distribution network in Gjakova is eliminated in order to reduce the losses and improve the quality of supply. N-1 criterion at 10 kV level can be accomplished through the interconnecting lines and cables between SS Gjakova 1 and SS Gjakova 2. Figure 5-5 shows a one-pole scheme that summarizes the two substations: SS Deçan and SS Gjakova 1.




Figure 5-5. Project's single pole scheme for transformer replacement in SS Gjakova 1 and SS Deçani

The expected benefits from the two aforementioned projects are:

- *Reduction of undelivered energy to customers in Deçan and Gjakova area*
- *Increased security and reliability of distribution consumption supply*
- *Support for further development of the distribution network 10 (20) kV*
- *Increased transformation capacities of 110/TM kV and fulfilment of N-1 criterion in transformation*
- *Optimization of maintenance process*
- *Support to the development of economic sector/industrial load.*

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 52 of 103</i>
<i>Office: Long-term Planning and Development</i>		

▪ **Projects (ID/013): New Line 110 kV SS Prizren 1 - SS Prizren 2**

The consistent growth of load in the Prizren region shall put at risk the fulfilment of N-1 criteria for that area of the transmission network. The second 110 kV line from SS Prizren 1 to SS Prizren 2 is necessary since according to the current network configuration, an outage of the line SS Prizren 2- SS Prizren 3 would cause an overload on the Line SS Prizren 2 – SS Prizren 1.

The project foresees:

- Transformation of the existing SS Prizren 2 – SS Prizren 1 (HW 173mm<sup>2</sup>) line to a double line with conductor 240mm<sup>2</sup> AlSt, using the existing track.
- The HW 173mm<sup>2</sup> conductors will be used for the revitalization project of the Prizren 1- Prizren 3 line, where the 150 mm<sup>2</sup> conductor with a capacity of 83 MVA will be replaced with HW 173mm<sup>2</sup> with a capacity of 114 MVA.

The geographic scope of the double line SS Prizren 2- SS Prizren 1 is shown in Figure 5-6, while the single line diagram is shown in Figure 5-7.

The project is due to be completed by 2025. This project is important for the realization of 110 kV consumption grouping concept as per main substations.

Expected benefits from the project are:

- *Enhancement of transmission capacities of 110 kV network*
- *Fulfilment of the N-1 criterion in long term period.*
- *Reduction of undelivered energy to consumer*
- *Optimization of power flows and enabling the grouping of 110 kV loads according to independent supply from main transmission system nodes (in this case from SS Prizren 2)*




Figure 5-6. Project of double 110 kV SS Prizren 1- SS Prizren 2




Figure 5-7. 110 kV double line SS Prizren 2- SS Prizren 1 and interconnection with surrounding substations

- **Projects (ID/023 and 050): Replacement of transformers in SS Theranda and SS Bibaj (Ferizaj 1)**

The existing 110/10 kV two-pole TR1 transformer at SS Theranda with 31.5 MVA power, due to operations under conditions constrained from overloads or frequent short circuits in that area, has expedited the aging of the transformer. This transformer has been rendered functional in 1985 and is still functional. The transformer will continue operation until expiration of the time period of 40 years, and the state of the transformer will be carefully supervised by operators and the maintenance team. This transformer should be replaced with a new two-pole transformer 110/10 (20) kV with 40 MVA power as shown in Figure 5-8.

The N-1 criterion at 10 kV level is supplemented by transformer capacities at the substation, while at 35 kV level, this criterion is supplemented by the interconnection of SS Theranda with SS Prizreni 1 with a 35 kV line, which can be used as reserve supply in case the three-pole transformer in SS Theranda fails.

The project is expected to become operational in **2025**.

Also the TR2 transformer with 31.5 MVA installed power and 110/35 voltage at SS Bibaj built in 1969 should be replaced with a new three-pole 110/35/10(20) kV transformer with 40/40/40MVA power. In this case, it is possible to fulfil the N-1 criterion for the transformer of 10 kV in the SS Bibaj, which is currently not met. The project is also expected to become operational in 2023.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 54 of 103</i>
<i>Office: Long-term Planning and Development</i>		




Figure 5-8. Replacement of transformers in SS Theranda and SS Bibaj, with new transformers 110/10 (20) kV, 40 MVA and 110/35/10 (20) kV, 40/40/40 MVA

#### **Projects (ID/053): Replacement of transformers in SS Peja 1, SS Prizreni 1**

The main reason for being included in the list of network reinforcement projects is to fulfil the N-1 security criterion at the 10 kV level in both Peja 1 and Prizren 1 substation. Initially both substations had transformers 110/35 kV, while in 2011 the DSO installed a new three-pole 110/35/10 transformer with 40 MVA power in both aforementioned substations. In this case the N-1 criterion at the 10 kV level cannot be fulfilled, while the maintenance of these transformers requires total disconnection of customers from the 10 kV busbars, for as long as there is maintenance of transformer.

In order to avoid this problem and increase security of supply, the project envisages that in 2025 the TR1 two-pole 110/35 kV 31.5MVA transformer is to be replaced in SS 110/35/10(20) kV Peja 1 built in 1985 with the new three-pole 40/40/40 MVA 110/35/10 (20) kV transformer.

Also in the same timeframe, the replacement of the TR1 two-pole 110/35 kV 31.5MVA transformer is planned in SS 110/35/10(20) kV Prizren 1 built in 1975 with the new three-pole 40/40/40 MVA, 110/35/10(20) kV transformer. Figure 5-9 shows the one-pole scheme of two substations with replaced transformers.

In this case, both substations will meet the N-1 criterion for both medium voltage levels: 35 kV and 10(20) kV.

The benefits of the project are attributed to increased security of supply for customers in the Peja and Prizren region, related to meeting the N-1 criterion in transformation as well as increasing the security of operation of transformers as a result of the replacement of transformers that in **2027** the one in Peja will be 40 years old and the one in Prizren will be 52 years old.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 55 of 103</i>
<i>Office: Long-term Planning and Development</i>		




Figure 5-9. Replacement of transformers in SS Peja 1 and SS Prizren 1, with new three-pole 110/35/10 (20) kV 40/40/40MVA transformer

The following are the expected benefits from the two aforementioned projects:

- *Reduction of undelivered energy to customers in Peja and Prizren area*
- *Increased security and reliability of distribution consumption supply*
- *Support for further development of the distribution network 10 (20) kV*
- *Increased transformation capacities of 110/TM kV and fulfilment of N-1 criterion in transformation*
- *Optimization of maintenance process*
- *Support to the development of economic sector/industrial load.*

• **Project (ID/055): New 110 kV SS cable Line Prishtina 2- NS Prishtina 4**

This new project, which was not included in the earlier development plans, was initiated as a result of the continuous increase of the load in SS Prishtina 3 and SS Prishtina 2. Computer simulations for the following years result in N-1 criteria not being met in the segment of 110 kV lines SS Kosova A - SS Prishtina 3 - SS Prishtina 2 - SS Prishtina 4. The outage of one of the lines SS Kosova A - SS Prishtina 3, or SS Prishtina 2 - SS Prishtina 4 results with an overload of the line that remained operational.

Two options were analysed for building a new line, i.e. one from SS Prishtina 4 to SS Prishtina 2, and the other from SS Prishtina 3 to SS Kosova A. The cost-benefit analysis determines the optimum solution in the technical-economic aspect of the construction of the new cable line XLPE AL 1000mm<sup>2</sup> with nominal thermal capacity of 114 MVA from SS Prishtina 4 to SS Prishtina 2.

The construction of this cable line maintains supply security for a large portion of the demand in the capital city. In this case, the N-1 criterion for this part of the network will be met in the long-term period. The cable track is not yet defined as the cable will pass through a significantly urbanized area of the Capital, whereby roads will be used as a potential track from SS Prishtina 4 to SS Prishtina 2, while trying to avoid private properties as much as possible so as to avoid the problem of expropriation. The approximate conceptual assessment of cable length is around 4.85 km. This length may vary depending on the final determination of the cable track.

The project itself contains also the installation of two 110 kV line fields, one in SS Prishtina 4 and the other in SS Prishtina 2. The technology of line fields may be selected as the hybrid "HIS" technology which takes precedence over "AIS" technology in terms of using less space for installation in substation. Figure 5-10 presents the single pole scheme of cable connection between SS Prishtina 4 and SS Prishtina 2.

Project is planned to be completed in **2026**.

Expected benefits from the project:

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 56 of 103</i>
<i>Office: Long-term Planning and Development</i>		

- Increased transmission network capacities of 110 kV
- Fulfilment of the N-1 security criterion in the long term
- Increased security of demand supply and reduction of energy undelivered to consumers in capital city




Figura 5-10. Single line scheme connection of new 110 kV cable line SS Prishtina 4-SS Prishtina 2

- **Projects (ID/059): Replacing transformers in SS Vitia, SS Gjilani 1 and SS Gjakova 1**

The main reason for inclusion in the list of projects to improve the network is the ageing of transformers and building capacities of transformers in three substations: Vitia, Gjilani 1 and Gjakova 1. The transformer in SS Vitia 20MVA, 110/35 kV built on 1974 will be replaced in **2027** by a three-pole transformer 110/35/10 (20) kV with a capacity of 40/40/40 MVA. In order to maintain the N1 criterion at the 10 kV level, the transformers 35/10 kV in SS Viti should remain installed but not energized. In case of maintenance of the three-pole transformer 110/35/10 (20) kV, the supply of the city of Viti can be transferred from 35 kV to 10 kV level by connecting the two existing transformers 35/10 kV located in SS Viti.

In that very same year (2027), is foreseen the replacement of the transformer 31.5 MVA, 110/35 kV in SS Gjilani 1, build in 1974, by a three-pole transformer 110/35/10(20) kV with a capacity of 40/40/40 MVA.

In the same year (2027) is also foreseen that in SS Gjakova 1 the remaining transformer 20MVA, 110/35 kV, build in 1974, will be replaced by the transformer 110/10(20) kV with a capacity of 40 MVA. Thereby, the supply with 10(20) kV for the entire city of Gjakova, consumption is achieved via two substations: Gjakova 1 and 2. The 35 kV network will remain as backup supply which will be necessary for further supply of

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 57 of 103</i>
<i>Office: Long-term Planning and Development</i>		

consumption in Xerxe, which is supplied through 35 kV and by SS Rahoveci. The interconnection of SS Rahoveci with 35 kV lines plays an important role in maintaining network reserves in case of unpredictable breakdowns in both concerned substations.

Figure 5-11 shows the simplified single pole schemes of substations where the transformers will be replaced.

The expected benefits of both abovementioned projects are:

- *Reduction of undelivered energy to customers in Viti, Gjilan, and Gjakova area.*
- *Increased security and reliability of distribution consumption supply*
- *Support for further development of the distribution network 10 (20) kV*
- *Increased transformation capacities of 110/MV kV*
- *Support to the development of economic sector/industrial load*




Figure 5-11. Replacement of transformers in SS Vitia, SS Gjilani 1 and SS Gjakova 1 with new transformer

▪ **Project Packet (ID/54): SS NASHECI (Prizren 4), 400/220/110 kV with the 400 kV interconnection line**

The development of the 400 kV network was realized in two phases: the first phase was realized in the 1980s and is related to the construction of TPP Kosova B which presented the need for construction of the first substation 400/220 kV and three 400 kV lines. This configuration remained unmodified until 2009 when the second phase of development of the network 400 kV commenced with the construction of the second substation 400 kV SS Peja 3, which had a 400/110 kV transformer. During 2011, was built the third substation SS 400/110 kV Ferizaj 2. Furthermore, in 2016, after 36 years, was built the new interconnection line 400 kV SS Kosova B-SS Tirana 2.

If we are to consider the geographical distribution of the system's load, the three areas: Prishtina with the surrounding areas, Dukagjini and South-East Kosovo are now supplied by the 400 kV network. Such configuration has avoided losses caused by transformations 400/220 kV and 220/110 kV, as well as from power transmission in 220 kV lines to distribution substations. Currently only the area of Prizren and its surroundings, including Rahovec, Gjakova and partly Theranda are supplied by the 220 kV network and the supply source is SS Kosova B and the interconnection line SS Prizren 2- SS Fierza.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 58 of 103</i>
<i>Office: Long-term Planning and Development</i>		

Computer simulations in complex models undertaken by **KOSTT** have shown that the network area of the Prizren region will not be compliant to the N-1 criterion after 2026, due to high impedance of two 220 kV supply lines of SS Prizren 2. A larger problem would occur if the 220 kV interconnection line Fierza-Prizren 2 would fail. In this case, voltage collapse may occur, coupled with the disconnection of the load at SS Prizren 2.

Kosovo-Albania market integration, establishment of ALPEX stock exchange implies intense exchange of power between the two countries in different seasonal regimes. Mainly, Albania will use the interconnection network during the summer season for imports from Kosovo TPPs when hydrologic conditions do not guarantee production by HPP, while Kosovo will provide regulatory reserves throughout the year from Albania's system, including imports to Kosovo power when Albania's system has surplus. The joint market will impose a change in the maintenance schedule of Kosovo TPPs and will require sufficient interconnection capacities that will be free to exchange regulatory power between the two systems for the needs of the System Operators. Adding the developments in the new generating capacities in Albania such as HPP Skavica and TPP Kosova e Re in Kosovo, the conversion of SS Prizreni 2 to substation SS 400/220/110 kV Nashec as well as the subsequent construction of the second interconnection line 400 kV HPP Skavica - SS Nashec beyond the planning period is seen as a real option which would help both countries as well as the regional network in the successful integration of small markets in the region of South-Eastern Europe. The project is optional and will largely depend on developments in the Energy sector in both countries and the region in the next 5 years.

The concept of re-establishing SS Prizren 2 in SS Nasheci with 400/220/110 kV transformation will entail the following benefits:

- *Enables the support for new generation capacities (Reversible HPP Drini)*
- *Increases the 400 kV network's reliability and security.*
- *Facilitates the security of power exchange between Kosovo and Albania and countries in the region, or transits going through horizontal network.*
- *Enables the reconfiguration of the 110 kV network with the aim of optimizing operational conditions of the transmission system*
- *Enhances the quality of consumption supply in the region of Prizren.*
- *Facilitates the 400 kV line maintenance process.*
- *Creates conditions for the construction of a second 400 kV line from HPP Skavica (Albania) to SS Nashec (Prizren 4).*

Project's technical details are as follows:

**Upgrading** the SS 220/110 kV Prizreni 2 into a three-level substation with 400/220/110 kV, which will be called SS Nasheci based on its existing location. The substation will initially have an auto-transformer of 300 MVA installed. The substation will be located in the open areas at the SS Prizren 2, wherein the 400 kV busbar system will be constructed, which will initially contain two line fields, a connecting field and a transformer field, along with the space for a line field and a 400 kV transformer field for future long-term developments. Figure 5-13 shows the configuration of SS Nasheci. The two substations will work in parallel on the 110 kV side, which means the use of existing 3x150 MVA autotransformers of SS Prizreni 2, by always optimizing their work depending on the demand of the network 110 kV accessed in SS Nashec.

Existing 220/110 kV auto-transformers will be utilized until the end of their lifespan, whereby two of them can be decommissioned in 2030, and the third transformer in 2050. They will be replaced by the installation of second auto transformer 400/110 kV after 2030. The existing 110 kV busbar system should be sectionalised in order to optimize the distribution of line fields and transformers and to achieve selectivity in busbar protection.

**The dual line 400 kV** shall be the supply line of SS Nasheci with a length of approximately 26 km, ASCR 2, 490 mm<sup>2</sup> with a capacity of 1330 MVA will be connected at the crossing point of the existing line SS Kosova B-SS Tirana 2 approximately in the 55th kilometre of the line from SS Kosova B. On this occasion, the existing line will establish the lines SS Kosovo B - SS Nashec with length of 81 km and SS Nashec - SS Komani with length of 56 km. After the construction of SS Komani 400/220 kV the line Kosova B-Tirana 2 was cut, where now the interconnection line is significantly shorter (142 km) as shown in Figure 5-12 which represents a part of the regional network. The solid lines in purple represent the lines that are expected to be operational in the next 5 years, while dash-lines belong to the long-term period. This configuration provides Kosovo's transmission with network stability and sustainability in operation, due to a high flexibility of shifting power flows in the event of opening one of the four abovementioned rings.



Figure 5-12 Geographical scope of the SS Nasheci Project in the regional network (ENTSO-E Map)




Figura 5-13. Single pole scheme of modified substation SS Prizren 2, 220/110 kV to SS Prizreni 4, 400/220/110 kV

#### 5.4.2.1 Projects: Re-vitalization of 110 kV lines

The important factors that are taken into account for determining the list of lines which will have the conductors replaced with larger transmission capacity are:

- The age of the lines,
- Line overload frequency (N-1), and
- The level of power losses in the line

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 61 of 103</i>
<i>Office: Long-term Planning and Development</i>		

The first factor is clearly defined; while the second and third factors are identified by computer analysis, thereby simulating load flows for different transmission system operation conditions, in due consideration of perspective development of projects, which would considerably impact the change of load flows in the transmission network. All 110 kV lines with 150 mm<sup>2</sup> section, in the transmission network, have been analyzed in terms of load losses, thereby pursuing reinforcement at the long term. Lines that are 40 years old and lines with larger overload frequency and, understandably, higher losses, are listed in the first place.

The main objective of this category of projects is to increase the capacity of 110 kV lines with section conductors of 150 mm<sup>2</sup> (83 MVA), in conductor 240 mm<sup>2</sup> (114 MVA). Some very old lines mainly have concrete towers and replacement of the existing conductors with conductor on greater weight in mechanical and statically terms require reinforcement of towers, with special emphasis on angular towers. In review is considered new technologies ACCC conductors (conductor aluminum, composite core) who have the same weight as 150 mm<sup>2</sup> conductors but the resistance and their carrying capacity is equivalent to 240 mm<sup>2</sup> conductor ASCR. Although the cost of ACCC conductors is two times higher than the equivalent conventional in lines where considered good technical condition of the columns, it is reasonable economically installing them. In the 2021-2030 period as in the following are selected 110 kV lines which will be reinforced.

- **Project (ID/012): Re-vitalization of line 110 kV, SS Prizreni 1 – SS Prizreni 3**

The project in question relates to the project of the dual line 110 kV SS Prizren 2 - SS Prizren 1. The conductor, which is currently located on the line SS Prizren 2- SS Prizren 1, is of type HW 173 mm<sup>2</sup> with a capacity of 114 MVA, during the implementation of the project will be dismantled and the same will be used to replace the 150 mm<sup>2</sup> conductor of the line SS Prizren 1 - SS Prizren 3. This will allow for cost optimization and build the desirable capacity of the lines.

The line represents the connecting segment for supplying SS Prizreni 3 as shown in Figure 5-14. The re-vitalization of this line will significantly affect the enhancement of security and operational reliability of that part of the 110 kV network.

Expected benefits from the project are:

- *Fulfilment of the N-1 criteria for the part of the network 110 kV that connects substations 110 kV in the region of Prizren*
- *Increasing transmission capacity of the line from 83 MVA to 114 MVA*
- *Reduction of unsupplied electricity*

Project is planned to be completed in the third quarter of **2025**.



Figure 5-14 Line 110 kV SS Prizren 1 – SS Prizren 3 with length 4.69 km

▪ **Project (ID/051): Re-vitalization of the 110 kV segment line SS Bardhi - SS Ilirida – SS Vallaqi**

Following the connection of SS Ilirida to the previous line SS Palaj (Bardhi) - SS Vallaq with section 150mm<sup>2</sup>, power flows in this line have increased, which has also increased its importance in terms of security of supply for the southern part of Mitrovica.

This line was built in 1958 (61 years). After a detailed review of the line's technical condition, it was concluded that the technical condition of the poles is not good. In a large number of poles, a continuous intervention is required due to the static problems of the pole's foundation. This implies that the line as such should be completely dismantled and rebuilt, while preserving the existing track, and existing poles should be used for the construction of new "Pine" type poles. The conductor will be standard 240mm<sup>2</sup> AlÇe, 38.5 km long and with a transmission capacity of 114 MVA.

Increasing the capacity of this segment SS Palaj-SS Ilirida-NS Vallaq would avoid its overload when the supply line SS Kosova A - SS Vushtrri 2 is disconnected. Figure 5-15 presents the part of the line planned to be re-vitalized.

Expected benefits from the project are:

- *Enhancement of line transmission capacity from 83 MVA to 114 MVA*
- *Reduction of active and reactive power losses*

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 63 of 103</i>
<i>Office: Long-term Planning and Development</i>		

- *Fulfilment of the N-1 criterion for the section of the network connecting the ring: Kosova A-Bardhi-Vushtrria 1&2-Trepça-Ilirida-Vallaq*
- The project is planned to complete at **2024**.




Figure 5-15 Line 110 kV SS Kosova A – SS Bardhi – SS Vallaq with a length of 38.5 km

- **Project (ID/052): Re-vitalization of line: SS Vallaq-border (N. Pazar)**

The line currently does not have sufficient capacity due to its sectional width (150 mm<sup>2</sup>). On the other hand, this line is one of the oldest lines of the transmission system of Kosovo, therefore its reinforcement is necessary. Replacement of the conductor is planned for 18.4 km of the line, starting from SS Vallaqi to the the border with Serbia. The project should be previously coordinated with Inter-TSO agreement with neighbour system. The construction of the SS Leposaviqi 110/35/10 kV, which will be connected in the section in the cross-border line SS Vallaq-SS N.Pazar, remains optional. The figure 5-16 shows the geographical position of the project. The project is planned to be complete in **2027**.

Expected benefits from the project are:

- *Enhancement of the line transmission capacity from 83 MVA to 114 MVA*
- *Reduction of active and reactive power losses*
- *Enabling the realization of SS Leposaviq 110/10(20) kV*




Figure 5-16 Revitalization project for the interconnection line 110 kV SS Vallac – SS N. Pazar

▪ **Projekti (ID/060): Re-vitalization of the line 110 kV SS Bibaj-SS Kastriot (L127)**

The connection of the planned substation of SS Kastrioti to the current SS Bibaj-NS Theranda line, with a section of 150mm<sup>2</sup> and the technical condition of the line built in 1973, are the main factors for the introduction of this project into the development plan of the transmission network. Based on technical assessments, the current line of SS Theranda - SS Bibaj, from the connection point of the SS Kastrioti to SS Bibaj with a length of 6.7 km should be completely dismantled and rebuilt using the same track and parcels of 24 existing poles as presented in Figure 5-17. The protective conductor containing the optic fibre will be used for the rebuilt line. The project reduces network losses and increases the capacity of the SS Bibaj-SS Kastrioti line from 83 MVA to 114 MVA. In the phase beyond the development plan period, the line segment to SS Theranda should also be rebuilt.

The expected benefits of the project are:

- *Increasing transmission capacity of the line from 83 MVA to 114 MVA*
- *Reduction of active and reactive power losses*
- *Use of full capacity of connection lines of SS Kastrioti (240mm<sup>2</sup>)*

The project is planned to be implemented in 2028.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 65 of 103</i>
<i>Office: Long-term Planning and Development</i>		



Figure 5-17. Geographical extension of the project for the reconstruction of the line segment SS Kastrioti-SS Bibaj (from the Connection Point to SS Bibaj)

▪ **Project (ID/061): Revitalization of 110 kV line SS Ferizaj 2-SS Sharr (L106)**

The line of SS Ferizaj 2- SS Sharr has two sections of conductors: the line segment from SS Bibaj to SS Sharr has the 150mm<sup>2</sup> section, while the line segment from SS Bibaj to SS Ferizaj 2 has the 240mm<sup>2</sup> section and represents parts of the large project SS Ferizaj 2 completed in 2011. Part of the line with 150 mm<sup>2</sup> section is one of the first 110 kV lines built in Kosovo in 1953. The main factor for the introduction of this project into the transmission network development plan is the ageing of lines and its technical condition. According to technical assessments, this 28.7 km long line should be completely dismantled and a new one must be built in the same track by using the pole parcels, as shown in Figure 5-18. The protective conductor containing the optic fibre will be used for the rebuilt line.

The expected benefits of the project are:

- *Increasing transmission capacity of the line from 83 MVA to 114 MVA*
- *Reduction of active and reactive power losses*
- *Increased line reliability.*

The project is planned to be implemented in 2029 when the line's age is 76 years since the start of its first operation.




Figure 5-18. Geographical scope of the project: re- construction of 110 kV line SS Ferizaj 2-SS Sharr starting from SS Bibaj to SS Sharr

### 5.4.3 Load support projects

The following are technical descriptions of projects supporting the load and expected benefits from them.

- **Project (ID/009/1): SS Kastrioti (Ferizaj 3) 110/35/10(20) kV**

The main factors that have led to initiating the construction of the second 110 kV substations in the Municipality of Ferizaj are the following:

- *High rate increase of demand for electricity as a result of increasing number of businesses and constructions,*
- *Endangering the security supply of customers,*
- *The high level of charge to substation SS Bibaj as a result of the supply of the customers of Kaçanik and Shtërpçe,*
- *N-1 non-compliant transformation criterion.*

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 67 of 103</i>
<i>Office: Long-term Planning and Development</i>		

Ferizaj is considered one of the regions with a rapid growth of small businesses and small industry with a comparatively similar comparison with the regions of Prishtina, Prizren and Peja. The supply of distribution points with only one 110 kV substation does not guarantee supply security and as such creates bottlenecks to the economic development of Ferizaj Municipality and the surrounding area.

The construction of the new substation will have an impact on the distribution of power flows from NS Bibaj to the new substation, thus avoiding the risk of transformers falling and causing large amounts of undelivered power to customers, with negative effects on businesses, industry and citizens.

At KEDS's request, the proposed location is on the exit of the city in the north-western part of the village of Leshkobarë. Based on the proposed location, the most optimal connection point is the existing 110 kV line SS Therandë-SS Bibaj. The intersection of existing line SS Theranda-SS Bibaj will take place at 5.7 km point of the line starting from SS Bibaj.

The supply line of SS Kastrioti will be double line with standard section 240 mm<sup>2</sup>, AIÇe 3.1 km with a length of 3.1 km near the substation where the switch to a cable line of 1000 mm<sup>2</sup> with a length of 0.3km to substation portals, will take place. Outputs 35 kV and 10(20) kV will be constructed by KEDS and will supply the part of consumption currently covered by SS Ferizaj II 35/10 kV. The main effects on loss reduction will be observed in the distribution network, avoiding losses in 35/10 kV transformers and 35 kV lines. Due to the cost, the substation will initially have only one power transformer with a capacity of 40 MVA, three-pole 110/35/10(20) kV installed. The 10 kV distribution network in a large part of the city can be converted to the 20 kV level by having an impact on the additional reduction of losses in the distribution network.

Figure 5-19 shows the position of the substation and the approximate track of connection lines, while Figure 5-20 shows the configuration of the connection in the single pole scheme of the transmission system.

Due to dual-line supply, the N-1 criterion is guaranteed for consumption up to 80 MW of new substation.



Figure 5-19. Configuration of connection of SS Kastrioti (Ferizaj 3) to the transmission network, approximate route of connecting lines

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 69 of 103</i>
<i>Office: Long-term Planning and Development</i>		




Figura 5-20. Connection configuration of SS Kastrioti (Ferizaj 3) in transmission network

Expected benefits of the project include:

- *Reliable and quality supply of Ferizaj consumption*
- *Relief of transformers in SS Bibaj*
- *Reduction of technical losses in the distribution network*
- *Reduction of significant amounts of undelivered energy to consumers as a result of eliminating bottlenecks in the network of distribution*

The project is scheduled to conclude in the fourth quarter of **2022**.

**Project (ID/004): SS Fushë Kosova 110/10(20) kV**

The list of priority projects from the perspective of KEDS includes the construction of the substation Fushë Kosova 110/10(20) kV, close to the existing substation 35/10 kV. The rapid development in the Municipality of Fushë Kosova, in terms of high constructions after the war, which is also ongoing, has resulted with a continuous increase of electricity consumption. This substation is currently supplied by two 35 kV lines, 95 mm<sup>2</sup> from SS Kosova A and SS Prishtina 1. According to information from KEDS, the 35/10 kV transformation capacities have exceeded the critical limit, while on the other hand the load in the Fushë Kosove region tends to increase steadily. For this reason, there is a need to create a new 110/35/10(20) kV node in Fushë Kosova, which should have sufficient long-term transforming capacities (2x40 MVA), which would be able to respond to the continuous load growth, in accordance with technical criteria of transformation reserve. The construction of the substation should allow for the relief of transformers at SS Prishtina 1 and SS Kosova A, and reduction of load flows in supply lines of the SS Prishtina 1. Under the EBRD-credited projects, the supply line infrastructure is under the implementation phase and is expected to be completed in the second quarter of 2020, and due to financial constraints, the substation is planned

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 70 of 103</i>
<i>Office: Long-term Planning and Development</i>		

to be built later through KFW lending (investment program, phases VI and VII). The infrastructure of the substation's supply lines comprises a 2.91km (360mm<sup>2</sup>-AlÇe) double overhead lines and a 1.23km double XLPE Al 1000mm<sup>2</sup> cable line.

The geographical position of the connection of SS Fushë Kosova is presented in the figure 5-21, while the connection of SS Fushë Kosova with the transmission network is shown in Figure 5-22.

Secondary side of the two transformers will be linked into the existing SS Fushe Kosova, 35/10 kV, eliminating voltage 35 kV. The dual connection of the substation enables the fulfilment of N-1 security criterion, allowing for sufficient secure supply of Fushe Kosova consumption.




Figure 5-21. Configuration of connection of SS Fushë Kosova in the transmission network (approximately conceptual route)

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 71 of 103</i>
<i>Office: Long-term Planning and Development</i>		




Figura 5-22. Connection configuration of SS Fushë Kosova in transmission network

Expected benefits of the project include:

- *Reliable and quality supply of Fushë Kosova consumption*
- *Relief of transformers in SS Prishtina 1 and SS Kosovo A*
- *Reduction of technical losses in the distribution network*
- *Optimal use of the converted line (Kosova A - Lipjan – Ferizaj 2)*
- *Optimization of power flows in 110 kV lines supplying substations of Prishtina as a result of the offloading of transformers in SS Prishtina 1 and SS Kosovo A*
- *Reduction of significant amounts of undelivered energy to consumers as a result of eliminating bottlenecks in the network of distribution.*

The project is scheduled to conclude in **2021**.

▪ **Project (ID/009): SS Dragash and 110 kV line SS Kukës-SS Dragash- SS Prizren 2**

Consumption of electricity in the region of Dragash and Zhur is realized through the distribution network 35 kV and 10 kV, extending in the southern part of the territory of Kosovo. The main supply line is 35 kV line connected to SS Prizren 1, 110/35/10 kV which supplies, in a serial connection, Zhuri and Dragash consumption. 35/10 kV substation is operating in Dragash, with two transformers of a total capacity of 8+4=12 MVA. Security of power supply for the areas in question is not satisfactory. During 2018 and 2019, KEDS has made some investments in the 35 kV networks which has significantly improved the highly critical

situation, but such a solution does not guarantee continued security of supply for Dragash and operation of RESs connected to the medium-voltage network to that area.

Elimination of the aforementioned problems in the long-term is achieved after the construction of a new substation 110/35/10(20) kV, with a capacity of 2x40 MVA in Dragash and 110 kV lines as shown in Figure 5-23.




Figure 5-23. Dragash and 110 kV line project with SS Kukes.

#### Expected benefits from the Project

Considering the Dragash region as an area with a high potential for development of mountain tourism and light industry, the construction of the new 110 kV substation will create optimal conditions to achieve the security of energy supply.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 73 of 103</i>
<i>Office: Long-term Planning and Development</i>		

The network configuration surrounding SS Dragash project and the connection with the current distribution network is shown in Figure 5-24.




Figure 5-24. Configuration of network project: SS Dragash and 110 kV interconnection lines with SS Kukes

Benefits that Dragash customers will have are presented as follows:

- *Increased security of electricity supply through two 110 kV lines*
- *Quality and reliable supply*
- *Efficient supply reducing technical losses in the distribution network*
- *Relief of power transformers in SS Prizren 1 to a load equivalent to the consumption in the region of Dragash*

The project also includes the construction of the 110kV interconnection line, which will connect, for the first time, the 110 kV transmission networks of Kosovo and Albania. Thus, in addition to the importance of the project to support the load of Dragash, this is considered a mutually beneficial project for Kosovo and Albania.

Expected benefits for both countries are listed as follows:

- *Optimization of power flow between the two systems Kosovo/Albania*
- *Mutual exchange of electricity surpluses through radial operation of the connection line.*

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 74 of 103</i>
<i>Office: Long-term Planning and Development</i>		

- *Increased security and reliability of supply for Kukes and its surroundings, as per the N-1 criterion, through reciprocal supply*
- *Increased quality and efficiency of supply of Kukes*
- *Increased security of supply for the consumption of the Kalimashi tunnel*
- *Optimal conditions for maintenance of the 110 kV network for both systems KOSTT/OST*

Project is planned to be in operation in **2025**.

▪ **Project (ID/011): Project Malisheva 220/35/10(20) kV**

The Malisheva Project was included in the list of capital projects for load support and strengthening transmission capacities of the network for the following reasons:

- a) The situation of supply for the Malisheva region is unsatisfactory, as this region is currently supplied by a 35 kV line from SS Rahovec. The great distance of this line causes significant losses of active and reactive power, thereby adversely influencing the quality of electricity delivered to consumers. The 35 kV voltage level and other distribution levels during the winter load are below minimum allowed values provided in the distribution code. To achieve a sustainable and long-term electricity supply for the Malisheva region, it is necessary to develop a 220/35/10(20) kV substation, with transformation capacities of 2x40 MVA.
- b) SS Malisheva will be connected to the 220 kV line SS Drenasi-SS Prizren 2, through a double line AIÇe 490 mm<sup>2</sup> with a very short length of about 50 m, as shown in Figure 5-25.

Figure 5-25 shows the geographical position of the Project. While the Figure 5-26 shows the unipolar configuration of the SS Malisheva connection in 220 kV network.




Figure 5-25 Geographical position of SS Malisheva (approximate conceptual position)




Figure 5-26 Single polar configuration of connection SS Malisheva in 220 kV network

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 76 of 103</i>
<i>Office: Long-term Planning and Development</i>		

Expected benefits from this project are:

- *Reliable and qualitative supply of Malisheva consum;*
- *Optimization of power flow and discharge of transformers in SS Rahoveci;*
- *Reduction of large amounts of energy not sent to the customer as a result of the elimination of bottlenecks in the distribution network;*
- *Reduction of technical losses in distribution network*
- *Support of economic development of Malisheva.*

Project is planned to be implement in **2022**.

#### **5.4.4 Projects: Substations Re-vitalization**

In determining the list of substations that required revitalization the following factors were taken into consideration:

- *Impact of the failure of the substations in the transmission system*
- *The age of the substation*
- *Frequency of the failures and damages in the equipments of the high voltage*
- *The level of the fault currents in the substations*

Probability of failures in high voltage equipment begins to rise with age of equipment, especially equipments that are greatly used. Also the substations which are characterized by large currents failures considerably influenced in the accelerating the loss of their credibility. Based on data archived in **KOSTT** related to the above mentioned factors a list was drafted of substations requiring revitalization in the first five years of the development plan.

- **Project (ID/017): Re-vitalization of line fields and 110kV transformers in SS Klina and SS Burimi**

Project re-vitalizing the 110 kV substation equipment above is underway and until the second quarter of 2025 is expected to be implemented.

Replacing them with modern equipment is important for safe operation of the transmission system. Investment reduces maintenance costs and increases operational safety and reliability of respective substations. The second transformer should initially be installed in SS Klina in order to enable the installation of the transformer field, without interruption of supply for Klina.

The project includes:

- *Replacement of third line fields - 110 kV, two in Burim and one in Klina*
- *Replacement of second transformer fields - 110 kV, one in Burim and one in Klina*

Expected benefits are summarized as follows:

- *Increased security and reliability of operation of respective substations*

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 77 of 103</i>
<i>Office: Long-term Planning and Development</i>		

- *Reduction of undelivered energy to customer*
- *Increased security of staff working in substation and maintenance*
- *Reduced maintenance costs.*

- **Project: (ID/022): Re-vitalization of the substation SS Vallaq**

SS Vallaqi is one of the first substations built in Kosovo. Revitalization of this substation is necessary because of the fact that its 110 kV busbars are connected with five 110kV lines, one of which transmits electricity generated by HPP Ujmani. The technical condition of the substation is not satisfactory and it threatens the safety and reliability of supply to consumers. Revitalization of the substation envisages the replacement of high voltage 110 kV equipment, replacement of the busbar system and its portals with the development of a double busbar system but with connection field. The project is scheduled to be completed in the fourth quarter of **2026**.

Expected benefits from the projects are:

- *Enhancement of the security and reliability of the substation operation*
- *Optimization of the operation of the substation after crossing the double busbar system*
- *Reduction of undelivered energy to customers*
- *Enhancement of security of staff working on the substation and maintenance staff*

#### **5.4.5 Projects: Advancement of the monitoring, control and metering system of the Transmission System**

The following are TDP projects considered necessary to fulfill the requirements of the Grid Code and **ENTSO-E** Codes and country regulations.

- **Projekti (ID/025) : Marking overhead lines for aviation security**

According to Regulation (CAA - Civil Aviation Authority) no. 03/2019 on Marking of Obstacles, KOSTT is obliged to implement this regulation. This Regulation defines the procedures for marking obstacles with visual signs and lights in the territory of the Republic of Kosovo for the purpose of making them conspicuous to aircraft and helicopters. Pursuant to Article 6 paragraphs 6.1 of the Regulation the following are included:

*6.1 Overhead wires, cables, etc., crossing a river, or valley and high voltage lines above 100 kV crossing a highway shall be marked and their supporting towers marked and lighted, except that the marking of the supporting towers may be omitted when they are lighted by high-intensity obstacle lights by day.*

The regulation also defines the method of marking the obstacles, namely the towers and other the conductors.

The project will be implemented in phases, during the period **2020 - 2024** since the installation of markings implies disconnection of lines and therefore time is required for its implementation because the opening of

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 78 of 103</i>
<i>Office: Long-term Planning and Development</i>		

interconnection lines, which largely cross over highways and roads, is done in a coordinated manner with TSO in the region.

The project is based on the aforementioned regulation and stipulates that the two towers which connect the lines crossing the main roads, or the valleys and rivers should be coloured white/red, with flashing lights on top. On the other side, the protective conductors should have white/red marking balls at a certain distance so that they could be seen by aircraft and helicopter pilots during day and night.

Throughout the three voltage levels 400/220/110 kV there are a total of 105 intersections with two highways and 4 lane roads that are built in our country. 400 kV lines intersect 14 times, 220 kV lines intersect 13 times, and 110 kV lines intersect 78 times, on four-lane highways and main roads.

Benefits from the project:

- *Increasing the safety of aviation flights in the territory of the Republic of Kosovo*
- *Avoiding fatal airplane and helicopter accidents.*

▪ **Project (ID/029): Upgrade of SCADA/EMS**

Considering that the existing SCADA/EMS system was designed based on the information technology, normative codes, and standards that have been used during 2008-2009 and based on recent technological developments and advancements in SCADA/EMS systems, which are integrated into the ENTSO-E TSO, our system can operate until 2021 under existing condition, and after that will have to be rebuilt based on the ever-evolving technological developments and requirements stipulated by ENTSO-E.

Below have been provided the facts showing the reason that the existing system should be rebuilt during 2022:

The project will include:

- 64-bit server hardware platform
- HDDs of ISCI and SAS technology with capacities of over 100GB
- Microsoft's latest Operating System
- Communication between the RTUs and the SCADA/EMS system shall be the IEC61970 standard or publicly known as CIM standard mandatory for application in Energy Management Systems (EMS) and required by ENTSO-E.
- Updating energy management systems in line with developments in the European market and changing and creating regional markets.
- This line includes the replacement of outdated hardware and upgrades to the existing system. Security is also expected to be improved by replacing the existing "firewall" with a more advanced firewall and the related software.
- New modules to be installed include:
  - TSO Cross-border Balancing Module.
  - Electronic procurement of broadcasting losses and other ancillary services.
  - Other modules that may be added as a result of the dynamism in ENTSO-E and the implementation of the KOSTT - ENTSO-E agreement.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 79 of 103</i>
<i>Office: Long-term Planning and Development</i>		

Based on all the facts mentioned, and KOSTT's fundamental and essential duty of secure and reliable operation of the Kosovo Transmission System in real time, the project is necessary at the time for which it is planned.

Expected benefits from the project:

- *Completion of technical requirements required by ENTSO-E in terms of SCADA/EMS systems*
- *Enhanced security of transmission system operation in terms of network operation in the ENTSO-E synchronous area*
- *Exchange of data with the Security Co-ordination Centres, which are expected to be soon developed in the region of South-eastern Europe, based on new formats and protocols for data exchange.*
- *Adequate protection from possible cyber-attacks that could endanger the country's security of supply.*

The project is planned to be operational in **2022**.

▪ **Project (ID/034): Migration to advance telecommunication systems**

Currently, KOSTT has a telecommunication network based on TDM technology that delivers various operating applications used in substations and control and centers for control and monitoring. Most applications are created and adapted to circulate through networks based on IP or Ethernet, such as SCADA, high voltage measurement, etc. Other sensitive remote protection applications still use dedicated transmission lines. However, due to the evolution of smart electrical networks, the ever-increasing need to reduce costs and increase efficiency and flexibility, require even the most critical services to connect to a telecommunications network. Moreover, there is a growing need for increased bandwidth in substations due to increased use of video surveillance and communications such as internet access or intranet across substations and main centers.

KOSTT's telecommunications network architecture is currently based on three different network technologies / layers: PDH, SDH and Ethernet / IP switching, which have been designed for over 10 years. Given the timeliness and rapid development of new technologies, it is not difficult to notice that further switching of time makes the existing network system increasingly nonflexible, complex and more expensive to manage and maintain.

The latest technologies and standards are increasingly being developed by the telecom industry to replace these three technologies / layers into a single, multiple, unified, high reliability network for all the necessary services. SDH and PDH transport technologies are TDM format, and now all KOSTT telecommunication network services are based on Ethernet / IP. Therefore, SDH and PDH infrastructure over time cannot support the flexibility required by Ethernet / IP protocols.

Expected benefits from the project are:

- *Bandwidth: to meet wider bandwidth requirements, respectively communication speeds for applications such as video surveillance etc.*
- *Network segmentation, for various services and applications*

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 80 of 103</i>
<i>Office: Long-term Planning and Development</i>		

- *The quality of the application, respectively setting the appropriate priority and network performance for individual applications*
- *Redundancy and network protection for highly required and required applications. For most applications, outages for activating the backup path should not last more than 50ms, as is the case with SCADA.*
- *Loss limitation, delays for critical time applications. In some cases delays should be non-existent, such as applications that still use PDH interfaces inherited as remotely protected.*

The project is expected to be operational in Q4-2025, which means that the current telecom systems will be exploited for the next 5 years.

#### **5.4.6 Projects of category: Generation support (in implementation)**

The technical details of two generation-related projects, which weren't included in the TDP 2016-2027 because of implementation uncertainties existing at the time of preparing the document, have been provided below. Projects of such nature, mainly in this phase, are related to the integration of renewable resources in the transmission network, confirmed by investors and with approved connection agreements. During the 2016-2017, a considerable number of renewable sources generator developers have also applied for connection to the transmission network, but they could not be included in this document as there are still implementation uncertainties, mainly because of developers' problems to ensure the investments. The costs of the transmission infrastructure allowing the connection of network generators are covered by the project developer, based on the connection taxes methodology, considering the technical boundary between the TSO and the Generator. After energization, the new high voltage assets are under KOSTT management, which means maintaining them until the decommissioning of the Generating Station. The maintenance cost is covered by the developer based on the connection taxes methodology approved by ERO.

- **Project (ID/056): Wind Park "SELACI" 105 MW**

WP Selaci with a capacity of 105 MW will be connected to 110/35 kV SS Vushtrria 1, through the 110 kV ASCR line, 240 mm<sup>2</sup>, 114 MVA with a length of 19.35 km, as shown in Figure 5-27.

The study shows that the connection of WP Selaci with a capacity of 105 MW in the transmission network in the aspects:

- *Power Flows-Criterion N-1*
- *Transient stability*
- *Short links*

does not affect the safety of the transmission system operation. The only concern remains the need for regulatory power and balance of the system in real time.

The computer simulations carried out for the various production capacities of WP Selaci and for various transmission system regimes indicate that the flows in the 220/110 kV transformers in SS Kosova A will be significantly reduced, helping to reduce transformation losses.

According to project investor predictions, WP Selaci is expected to be operational in **2021**.




Figure 5-27 Configuration of the Selaci 1.2 & 3, 105 MW Wind Park connection to the Transmission Network

▪ **Project (ID/057): Hydropower plant “LEPENCI” 9.92 MW**

The planned hydropower plant is located near the highway M2 (Prishtina-Hani i Elezit) 2.1 km near Hani i Elezit.

Figure 5-28 shows the configuration of the HPP Lepenci connection, 9.92 MW in the transmission network, respectively in the existing line SS Ferizaj 2- SS Sharri. The hydropower plant consists of three generators with visible power: G1=5.1 MVA, G2=5.1 MVA and G3=1.6 MVA. The planned substation will contain a 12 MVA transformer, with 35/110 kV voltage.

It is apparent that any electrical power injection at the 110 kV level of the transmission network has positive impacts. During the computer analysis of the EES model of Kosovo in which HPP Lepenci was modelled, the following impacts were observed:

- An injection of 10MW in the transmission network reduces power flows in the SS Ferizaj 2- HPP Lepenci line for 10 MW
- Affects the reduction of active and reactive losses
- Helps in accomplishing our country's goals for meeting EU Directives by improving the level of energy production from renewable sources




Figure 5-28 Configuration of the Lepenci HPP 9.92 MW connection in the transmission network

- **Project (ID/20): Supply and Installation of Solar Panels and Energy Efficiency at KOSTT Substations**

Energy efficiency and development of renewable resources represents one of the important objectives in the Energy Strategy 2017-2026. In this regard, KOSTT, in discussion with its international partners kfW, has ensured a grant covering the installation of solar (photovoltaic) panels in the roofs of KOSTT substation facilities, as well as improving the energy efficiency of facilities according to European standards.

The substations of KOSTT, while performing fundamental functions of supplying national consumption electricity, spent an amount of energy which is used for the following:

- The supply of equipment installed in the substation (relay, AC/DC systems, SCADA systems and measurements, circuit breaker, separator motors, cooling of transformers, telecommunication etc.)
- Interior and exterior lighting
- Air conditioning for equipment and commanding facility
- Environmental heating for equipment and personnel during the winter season

The electricity used for covering the aforesaid functions is realized through the self-transformation of the substation from the medium 10 kV voltage to 0.4 kV, and in certain cases from the reserve distribution line provided by the DSO.

The level of energy consumption depends mainly on the number of elements installed in the substation, the magnitude of the commanding facility and the level of energy efficiency of facilities (wall isolation, windows, roof etc)

The project is divided into two components:

- Installation of solar panels (in the roofs) and electric systems for converting and connecting to the 0.4 kV network of the substation
- Improving energy efficiency of KOSTT's substations facilities according to European standards (isolation, lighting, efficient consumer)

Electricity consumption for own needs of several KOSTT substations has been presented in Table 5-8. Substation with larger consumption is SS Kosova B, whereas consumption for other substations ranges from 60000 kWh to 190000 kWh.

Table 5-8. Annual electricity consumption of several KOSTT substations

SUBSTATIONS	Yearly consumption MWh
<b>Kosova B</b>	<b>1,050</b>
<b>Lypjani</b>	<b>191</b>
<b>Prizreni 1</b>	<b>136</b>
<b>Prishtina 1</b>	<b>132</b>
<b>Ferizaji 1</b>	<b>121</b>
<b>Vushtrria 1</b>	<b>74</b>
<b>Peja 2</b>	<b>66</b>
<b>Vushtrria 2</b>	<b>62</b>

Expected benefits from the project

- *Reduction of energy consumption costs from KOSTT substations, which is returned as consumer benefit*
- *Reduction of CO2 emission*
- *Supporting the fulfilment of national targets based on the efficiency program.*

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 84 of 103</i>
<i>Office: Long-term Planning and Development</i>		

## 6. ENVIRONMENTAL IMPACTS

### 6.1 Environmental protection

Continuous caution for environment will be part of the overall **KOSTT** Policy and engagement of this police is addressed in the certification of **KOSTT** with ISO 14001:2004 Standard. **KOSTT** Development Plan will take measures to prevent and correct any mistake that is referred to the environmental protection in accordance with the internal and external legal bases. Negative impacts mainly include terms of the impact of electromagnetic fields (EMF), noise and visual impact on the environment (more important effects). It is a primary objective for KOSTT for the future to put particular attention to gaps, which can directly or indirectly affect the health and wellbeing of the KOSTT staff, and certainly the health and wellbeing of parties outside of KOSTT.

### 6.2 Environmental problems in the transmission system

One can say that the Environmental problems in the transmission system are divided into following:

- Environmental problems caused by the lines, and
- Environmental problems caused by the substations

#### 6.2.1 Environmental problems caused by the lines

Today when needed energy necessary for the development of our country, appeared in the Development Plan, we need to adjust the priority of claims being aware of their impact on the environment. Therefore we can say that the priority is set towards a necessary development of electricity transmission of high voltage (during the above elaboration this need is reflected and justified), not to eliminate the need to minimize the possible impacts on the environment.

Most of the lines pass through the agricultural areas, while a little less of those lines that pass on the mountain ecosystems where their impact is not so expressed.

From the aspect of electromagnetic radiation, greater influence has the industrial frequency electromagnetic fields. The research of harmful effects of this type of non-ionizing radiation on man have not yet given the final answer, but it should be noted that nowadays there is a special interest for the possible effects of electromagnetic fields on electrical equipment as well as on the living creatures, especially on people. On the moment of the legal sanction of electromagnetic impact this plan will take into consideration and will be subject to **TDP's** implementation.

Therefore KOSTT will soon have adequate recordings for most sensitive aspects of environment impact, aiming to adapt to the requirements recommended by the WHO. We also have to monitor the causes of faulty automatics actions, reduction of the signal-noise ratio in communication and transmission equipment, and other important impacts, summarizing the necessary and required data.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 85 of 103</i>
<i>Office: Long-term Planning and Development</i>		

### 6.2.2 Environmental problems caused by the substations

Besides occupying the surfaces substations carry the biggest visual changes in their surroundings, but in aesthetic terms do not affect significantly, since under the rules they should be located outside residential areas. The continuous noise caused (transformers work) or the non-continuous work (disconnection equipment/circuits), the most direct impact on the environment of substations, and due to vegetation relief is rarely transferred to the residential areas, but in the substations location is likely to have greater value than those allowed. This will be determined soon, and adequate measures are likely planned and undertaken.

In modern equipment, breakers/disconnections include inert gas, hazardous for human health of not used properly and sufficiently (timelines are specified and gas releases must be sporadically measured), but have a undesirable impact in the ozone layer and with toxic products in small concentrations, which are caused during the working process in equipment.

Having in mind that there are strict procedures in accordance with international rules, in the use and maintenance of SF<sub>6</sub> circuits, it is proposed that the implementation of SF<sub>6</sub> technology, is ensured after a period of time, when we consider the need to add gas, detectors issuing leaking warning near the switch, followed by measurements of compensated amounts, and also through adequate measurements, so that the risk index will be brought to minimum.

Large quantities of synthetic oils found in power transformers, while a little less in the high voltage equipment. Having in mind that oils possess a high potential for environmental pollution, adequate measures are taken, such as the construction of collecting pool and protection for collections of any oil leakage. These pools at the same time are a kind of prevention in cases of large failures likely to occur.

After the second half of 2012, 28 other facilities of SS 110/TM kV have been integrated in KOSTT, for which GAP-analysis – non-conformity analysis have been carried out, which should be oriented with ToR towards appropriate improvements, the same as with earlier SS of KOSTT; this is a perspective of objectives in development plans of environmental aspects in KOSTT with regards to substations

### 6.2.3 Caution on the other environmental impacts

At a time when the need for more and more energy is growing, the real impact on the environment and aims for qualitative protection of this segment including this **TDP** that supports the following:

- Reduction of emissions in water, air and land
- Increase of energy efficiency
- Enforcing preventive measures in order to reduce the number of accidents
- Addressing remains, particularly hazardous ones
- Possibility for recycling in many functional forms, including in indirect ways
- Development of systems for data collection and database (electronic forms)
- Reduction of parts and equipment that are outdated
- Follow-up of gaps in the Line system
- Drafting documentation for this Transmission segment
- Construction of dual lines, where there are possibilities to rationalize the use of surfaces and corridors
- In general, the improvement of corridor occupation for transmission, where possible

All these are implemented in preliminarily planned time frames, such as:

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 86 of 103</i>
<i>Office: Long-term Planning and Development</i>		

- Reducing the damage done in the past
- Reduce the impact of ongoing activity in the relevant sector, and
- Prevention of pollution from activities in the future (e. g. EIA - Environmental Impact Assessment and preventive measures in proper reduction)

#### 6.2.4 Activities and advancements during the period

1. Compilation of numerous documents on environment and protection from corrosion.
2. One of the important KOSTT projects, which was finalized during the period, included the analyses of toxic oil matters (PCB and PCT) in power transformers. The analyses revealed good results, as no PCB or PCT traces are found in any of the transformers possessed by KOSTT. The said analyses were performed in an Italian laboratory licensed for such examinations – in this aspect, the green mark is our protective sign.
3. KOSTT started to conduct measurements of environmental impacts in its staff's healthcare. A report on such impacts, conducted through contemporary instruments, was prepared to this end. The repetition of these relevant parameters and the impact in our lines (external impact) to external parties will be performed soon.
4. Noise impact in detected and monitored locations, in direct vicinity of our staff's workplaces, was also analyzed and new protective equipment for our staff was ordered.
5. Regarding waste, we were incorporated in the Municipal Recycling Project, and have drafted the Initial Project for paper and plastic waste recycling.

#### 6.3 Environmental plans

In favor of the implementation of the requirements for environmental protection is the well supported initiative in setting environmental policy in **KOSTT** which is under the procedure to be adopted. Clear definition of environmental issues in **KOSTT** and orientation on what will be done to control the environment, means planning. Planning is accomplished through new projects, which are followed by the Environmental Impact Assessment. The implementation is started by established the organizational structure, staff responsibilities, competencies and training. Communication practices, control of documents and procedures, operational control and emergency preparation, define the operational part of the program. These points are also included in the **EMS** Manual (Environmental Management System) which will document a program that has determined objectives and targets to be achieved. This Manual was developed and has 18 procedures included which will be complemented with the Operational part, based in practical requirements of the Transmission Operator and its operational plans. These, along with routine monitoring conducted in the period 2014 – 2023, reporting the situation recorded along with appropriate recommendations, constitute a program of controlling acts and corrective ones in **EMS**. Finally, a review of routine management activities is lowed by the highest level in **KOSTT** the aim of which is to ensure future environment protection and sustainable development.

The long term environmental planning will support the benefit and **KOSTT** development plan, by aiming:

- Proper financial management, which directs a better environmental control

Work in due prevention needs to be adjusted to legal requirements. Therefore all operational parts that have impact in environment will be included in **KOSTT**, controlling the costs and its impact in the overall budget.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 87 of 103</i>
<i>Office: Long-term Planning and Development</i>		

In addition to this, the following elements shall be respected:

- Domestic legislation (environment, energy)
- EU Legislation (environment, energy)
- Technical codes in **KOSTT**
- International standards and norms
- Conventions signed, etc.

For all these requirements, necessary documents for work were issued.

More needs to be done to improve and update of the new technologies and in improvement of the infrastructure of the operation system (**SCADA**) and transmission system (construction of the double and triple lines. The world has advanced much in terms of environment, and we have to progress in achieving the required and targeted goals.

## 7. EXPECTED RESULTS FROM TDP 2021-2030 IN THE TRANSMISSION SYSTEM DEVELOPMENT

The Kosovo transmission system must be continuously developed in a manner of allowing for a secure, reliable and quality supply of consumption, pursuant to technical requirements of the Grid Code and the Operation Handbook of **ENTSO/E**. An adequate and sustainable transmission system development provides for favorable conditions of development of conventional and renewable generation capacities. Appropriate long-term planning for transmission system development is essential to meeting the abovementioned requirements. **The Transmission Development Plan 20218-2030** has identified medium and long term needs for infrastructure projects, necessary for the enhancement and maintenance of the operational performance of the system, in relation to development in consumption, generation and regional energy markets.

The **TDP 2021-2030** sets forth the development priorities broken down by categories and implementation timelines. The full implementation of transmission development plans is challenging even for most developed countries. Difficulties in accessing property, global economic crises, lack of financial resources, and social implications, are some of the factors which may slow or prevent the realization of projects which are necessary to be taken into account by planning engineers. Positive impacts of completed and ongoing projects have been analyzed in the previous development plan, while the following are general comments on new development projects presented in the **TDP 2021-2030**.

Developments in the last 5 years in the transmission system have created conditions for **KOSTT** membership to **ENTSO/E**. Regarding policies arising from **ENTSO/E** Operation Handbook related to technical requirements to be fulfilled by each TSO, with its recent investments to increase transmission capacities, raise security and reliability of the system as well as development of modern systems for measurement, monitoring and control, **KOSTT** is in the same, or possibly better position than some of the regional TSO-s which are already members of **ENTSO/E**. With development of the secondary control project which represents one of the main technical requirements for membership in the **ENTSO/E**, **KOSTT** will be fully ready for membership. Given the activities for the establishment of a common market with Albania and joint operation of both systems, the accession process to **ENTSO/E** shall not have any technical restriction.

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 88 of 103</i>
<i>Office: Long-term Planning and Development</i>		

## 7.1 Actual state of the network in 2020

The current transmission system of the Republic of Kosovo operates under optimal conditions as a result of investments made in the last decade. The number of unplanned outages of lines and transformers, the amount of energy not supplied is satisfactory reduced compared with the previous period when the transmission system was not developed in coherence with the development of the system load.

The system under normal condition (**N criteria**), in all modes of operation with maximum load and minimum are operating optimally. In the last three years, was noted an increase in the horizontal network voltage level; this increase is mainly noticed in 400 and 220 kV level, as presented in figures 7-1 and 7-2. Throughout several periods, particularly during the summer regime of system operation, the voltage level exceeds the nominal maximal values set by the grid code. This high level voltage creates great constraint to the insulation of 400 kV equipment, risking dangerous failure of busbars system and on the other hand impact the reduction of equipment lifespan and increasing losses in transformer cores (losses in iron). This problem cannot be solved in isolation by KOSTT alone, as this is a regional problem resulting from the construction of numerous 400 kV lines in the region and without the compensation of reactive power. On the other hand, the load level of the horizontal network of South-East Europe Network was reduced due to the economic recession in the region. This problem a few years ago has occurred in the horizontal network of Croatia, Bosnia and Herzegovina, whereas gradually expanded in the areas close to our transmission network. Operationalization of the new 400 kV lines in the region without adequate compensation with a low load level caused the presence of surplus of reactive power capacity, thus significantly increasing the voltage level. This problem cannot be solved in an isolated manner by the individual TSOs; therefore, a regional study is being carried out currently and will define optimum points for installing inductive reactors, which would have an impact on brining the voltage level within the allowed level. Operation at high voltage is not good for the electro-energetic appliances as it causes high constraints to the isolation and increases losses in the transformers core. KOSTT, by changing the network typology and in cooperation with neighbour TSOs, has tried to manage the voltage levels so they do not exceed critical values. This is mainly achieved with the disconnection of parallel lines and lines with low level of loads, through the coordination of National Dispatch Centres, in compliance with agreements between TSOs.




Figure 7-1. 400 kV voltage profile every 15 minutes, recorded from SCADA for 2020 (January-August)




Figure 7-2. 220 kV voltage profile every 15 minutes in SS Kosova B recorded from SCADA for 2020 (January-September)

The level of power losses is included in the saturation zone and almost is the same as with two previous years. The greatest losses are usually caused in 110 kV lines, while the horizontal network losses are dependent on the balance of the system as well as power electric transits flowing in our network. Table 7-1 shows the level of power losses calculated from simulations with PSS/E for the maximum load of the system 1258 MW. The lines share dominated in terms of total losses in transmission network with **68.8 %**, whereas transformers with **31.2 %**. It is noted that transformers transferred from DSO to KOSTT caused about **19.9 %** of total power losses. Comparing losses to those of previous year, it is noted an increase in transformer losses caused by the increase of transformers in the last two years. A large part of losses (around 4 MW) is attributed to losses in iron. These losses depend on the voltage; therefore cause significant losses of active energy, which is around 35 GWh. In general, as far as the balancing of system reactive power is concerned, throughout most of the year the network is balanced, namely during minimum loads the system is over-compensated, while during maximum loads the system needs around 60 MVAR which are obtained from local generators and interconnection.

Table 7-1. Participation of lines and transformers in transmission network losses -2020 during maximum load

<b>Power Losses / Topology Q4- 2016</b>	<b>P(MW)</b>	<b>Q(MVAr)</b>	<b>ΔP(%)</b>
Total losses in 400 kV lines	1.7	-116.5	7.4
Total losses in 220 kV lines	3.1	-18.5	13.4
Total losses in 100 kV lines	11.1	3	48.1
<b>Total losses on transmission lines</b>	<b>15.9</b>	<b>-132</b>	<b>68.8</b>
<hr/>			
Total losses in 400/220 kV transformers	0.4	21.2	1.7
Total losses in 400/110 kV transformers	0.8	19.9	3.5
Total losses in 220/110 kV transformers	1.4	44	6.1
Total losses in distribution transformers	4.6	85.1	19.9
<b>Total losses in transformers</b>	<b>7.2</b>	<b>170.2</b>	<b>31.2</b>
<b>Total losses in the transmission network</b>	<b>23.1</b>	<b>38.2</b>	<b>100</b>

In aspects of N-1 criteria, when an element falls off surprised, in transmission network are still occur constraints relatively small compared with previous years and especially if consumption is higher than 1260 MW. In the following table 7-2 presents the critical failures and critical system elements analyzed through computer simulations in PSS/E.

Tabela 7-2. Lista e rënive kritike dhe elementeve kritik te sistemit 2020

<b>Criteria analyses N-1 , peak 1258 MW</b>				
<b>No</b>	<b>Critical failure of line Q4-2020</b>	<b>Overloaded element</b>	<b>It[%]</b>	<b>Busbars with voltage drops &gt; 10%Un</b>
1	L 110 kV Prizren2-Prizren 3	L 110 kV Prizren 2-Prizren 1	106	The voltage remains within the limits set by the Grid Code
2	L 110 kV Prizren 2-Prizren 1	L 110 kV Prizren2-Prizren 3	103	
3	L 110 kV Prishtina 4-Prishtina 2	L 110 kV Kosova A-Prishtina 3	101	
4	L 110 kV Kosova A-Prishtina 3	L 110 kV Prishtina 4-Prishtina 2	101	
5	L Ferizaj 2-Ferizaj 1	L Ferizaj 2-Ferizaj 1	105	

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 91 of 103</i>
<i>Office: Long-term Planning and Development</i>		

Over the next two years part of the network that connect SS Prizren 2 and SS Prizren 1 and Prizren 3 will continue to remain a critical for larger loads than 1260 MW. However, this problem may be avoided with specific network configuration, namely by opening the line Prizren 3- Theranda. Loads over than 1260 MW has probability about 0.18% (16 hours per year) to happen in the next two years, so the impact on the security of the system will be relatively small. The problem in this part of the network will be solved after the commissioning of the new line 110 kV SS Prizren 2 – Prizren 1 and re-vitalization of line Prizren 1 - Prizren 3. There is no voltage problem with regards to criterion N-1, which means any unplanned decrease in an element (line or transformer) the voltage in the transmission network busbar will remain within the allowed voltage range according to the Grid Code. On the other hand, the constant increase in demand in the Capital city has pointed out that the failure of one of the lines SS Kosova A- SS Prishtina 3, or SS Prishtina 2- SS Prishtina 4, during peak load, can overload the respective lines as shown in the table 7-2.

If we refer to the short time where the transmission network does not meet the N-1 criterion, it can be said that the transmission network in terms of 400, 220, 110 kV lines and auto-transformers meets the N-1 criterion.

However, in the aspect of transformation, substations 110/35/10 kV still have nodes which do not fulfil the N-1 criterion. However, a part of the reserve supply in case of transformer outage may be realized through distribution network 35 kV and 10 kV. From 28 substations supplying the distribution network, 20 substations fulfil the N-1 criterion in terms of transformation, 3 substations fulfil the N-1 criterion through the 35 kV ring network, and 5 substations do not fulfil the N-1 criterion. These substations have a dual voltage system, whereby the 35 kV network fulfils the N-1 criterion, whereas the 10 kV network, upon line failure or during maintenance of transformer 110/35/10 kV, cannot be supplied. Such substations are: SS Prishtina 1, SS Ferizaj 1, SS Prizreni 1 and SS Peja 1, whereas SS Klina has only one transformer 110/10 kV.

## **7.2 Development of the transmission network capacities in the next 10 years**

Implementation of planned projects determined from planning process of CBA will enable the continuous development of internal capacity in the network which will create favorable conditions for the safe and efficient supply of consumption, as well as will create favorable conditions for the generation support. Constructions of new substations, 110 kV lines, and construction of SS Nasheci 400/110 kV, will be key reinforcements that will result in enhancing the capacities of the transmission network. The figure 7-3 shows the network's internal capacity building diagram in relation to the load for the next 10 years according to three scenarios of peak development. Since 2010, the transmission network has been operating with sufficient transmission reserves and with an increased trend in terms of N security criterion. This means that under the conditions of maximum load system operation, wherein all network elements are operational, no critical values of electricity and voltages are noticed in any of the lines, transformers and transmission system busbars.




Figura 7-3 Development of internal (vertical) network capacities in relation to load development for the next ten years

The capacity of the interconnection lines of the transmission network in Kosovo will be much higher than the needs for imports, or opportunities for exports of electricity that our country will have in the next 10 years and considering the volume of significant transit flows (in our network) for the region needs. But on the other hand in the regional network may appear restrictions that are difficult to realize high volume of imports. In most cases the net transmission capacities provided by the TSO-s in the region, are significantly lower than they are in reality.

Figure 7-4 shows indicative values of the simultaneous interconnection capacity (KNTI) for export and import calculated in a regional model and generation adequacy assessment for two development scenarios. Calculated capacity are taking into consideration the N-1 criteria for all horizontal network of the transmission systems in the region. If we refer to planned generation developments in Kosovo, horizontal network will be capable of accommodating significant generation capacities in full compliance with the technical criteria required by **ENTSO-E**.

Figures 7-7 till 7-13 shows the geographical maps and the single line diagram of the system of Kosovo for three periods: 2020, 2025 and 2030.




Figure 7-4 Simultaneous development of interconnection capacity in relation to the generation adequacy for the next 10 years (reference: Generation Adequacy Plan 2019 – 2028)

### 7.3 N-1 security criterion

Looking at the situation in the network before 2009, the N-1 security criterion wasn't met even in summer consumption, while in normal operation conditions, the network would be subject to overloads which were managed by load shedding.

Full implementation of the N-1 security criterion requires considerable investments. Considering the development processes planned for the next 10 years, the security criterion will be fully complied with only after 2019, while if not taken into account radial lines SS Rahovec - SS Theranda. There are still some hours that network does not meet the N-1 criteria as presented in Table 7-2, but in practical aspects these hours can be avoided with some specific 110 kV network configurations. The N-1 criteria almost completed since current year with some specific configurations of 110 kV grid. The N-1 criterion in 220/MV kV and 110/MV kV substations, due to the high cost and tariff implications, will not be completed entirely but, in coordination with KEDS, technical possibilities will be examined to partially complement this from reserves in the distribution network. Figure 7-5 shows the ability of the network to fulfil the N-1 security criterion, in relation with the maximum load for the next 10 years, for the three load scenarios.




Figure 7-5. N-1 capacity development of vertical transmission network 2009-2030

#### 7.4 Quality of supply and efficiency

Figure 7-6 illustrates the impact of investments in the reduction of losses and indirectly confirms the improved quality of supply. The figure shows that the level of losses has entered the saturation area, with a trend of slight increases in absolute values, but in relative terms, they will almost remain at the current level. In 2016 was noticed a significant increase of losses for 10 GWh caused by a long-term operation with open rings of the 110 kV network due to implementation of projects such as: lines 110 kV Peja 1- Peja 3 and Deqan-Peja 2.

The no load operation of line 400 kV Kosova B-Tirana 2 had significantly increased the losses of active power during 2016 and 2017. Reactive power injected in busbars of SS Kosova B reached to 156 MVar and this power reflected in capacitive electricity creates continuous losses in conductors. Following the construction of SS Komani in Albania and shortening of Kosovo-Albania interconnection line from 243 km to 142.2 after cutting the line, the reactive power injection at the SS Kosovo B busbars has been reduced. A part of additional electricity losses is attributed to losses greater than the nominal value in the transformer core due to operation of the transmission system with increased voltage levels. Therefore, in order to reduce the transformer iron losses, KOSTT applies the regulation for optimizing the work of autotransformers, whereby in the period of loads from May to October, they periodically disconnect some autotransformers, always taking care that the N-1 criterion is always met.




Figure 7-6. Active energy losses in the transmission network 2007-2019 and forecast 2021-2030




Figure 7-7. Development of internal capacities of the transmission network 2006-2020




Figure 7-8 Single line diagram of Kosovo EES according to December-2020 network topology




Figure 7-9 Single line diagram of Kosovo EES according to 2025 network topology




Figura 7-10 Single line diagram of Kosovo EES according to 2030 network topology




Figure 7-11 Kosovo Power System according to 2020 topology




Figure.7-12. Kosovo power network topology 2025




Figure 7-13. Kosovo power network topology 2030

	<b>TRANSMISSION DEVELOPMENT PLAN</b>	<b>DT-PA-001</b>
	<i>ver. 0.1</i>	<i>page 103 of 103</i>
<i>Office: Long-term Planning and Development</i>		

## REFERENCES

The following are references made on published studies and reports:

- [1] Transmission Development Plan 2020-2029 /**KOSTT**
- [2] Long term energy balance 2019-2028/**KOSTT**
- [3] Generation Adequacy Plan 2019-2028/**KOSTT**
- [4] List of new Transmission Capacities and Interconnection Lines 2019-2028/**KOSTT**
- [5] Grid Code – second edition, 2.4/**KOSTT**
- [6] Electrical Equipment Code, /**KOSTT**
- [7] Transmission Connection Charging Methodology, /**KOSTT**
- [8] Transmission System Security and Planning Standards/**KOSTT**
- [9] Operating Security Standards/**KOSTT**
- [10] Law on Energy
- [11] Law on Electricity
- [12] Electrical Standard Code/**KOSTT**
- [13] Distribution Code/ **KEDS**
- [14] ENTSO-E SOGL
- [15] Energy strategy of Kosovo 2017-2026
- [16] ENTSO-E TYNDP
- [17] International Standard ISO 14001: 2015

(End of the document)

	Përgatiti	Kontrolloi ISO 9001	Aprovoi
Emri Mbiemri	Dr.Sc. Gazmend Kabashi		
Nënshkrimi			
Data	31.10.2017		